NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED MAR 20 1969 STATE ENGINEER SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print) (Do not write above this line)

SG 4802 525 MAR 1...

State Well No. 6/3W-26

State Permit No.

(1) OWNER:
Name CITY OF SALEM - PARKS AGENCY
Address 22ND + HOWARD ST. S.E. SALEM

(2) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☑ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☑ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☑
10" Diam. from +1 ft. to 81 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☑ Yes ☐ No.
Type of perforator used MILLS
Size of perforations ½ in. by 2 in.
perforations from ft. to ft.
116 perforations from 47 ft. to 63 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☑ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.
Static level 20 ft. below land surface Date 2-7-69
Artesian pressure lbs. per square inch Date

(9) WELL TESTS: Drawdown is amount water level is lowered below static level MILLER
Was a pump test made? ☑ Yes ☐ No If yes, by whom? ROBINSON + WEST
Yield: 285 gal./min. with 5 ft. drawdown after 12 hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? ☐ Yes ☑ No

(10) CONSTRUCTION:
Well seal—Material used CEMENT
Depth of seal 21 ft.
Diameter of well bore to bottom of seal 15 in.
Were any loose strata cemented off? ☐ Yes ☑ No Depth
Was a drive shoe used? ☑ Yes ☐ No
Did any strata contain unusable water? ☐ Yes ☑ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☑ No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:
County MARION Driller's well number
¼ ¼ Section 26 T. 6 S R. 3 W W.M.
Bearing and distance from section or subdivision corner
(SPONGS LANDING)

(12) WELL LOG: Diameter of well below casing 10
Depth drilled 96 ft. Depth of completed well 96 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
BROWN - SANDY CLAY	0	18	
" - " "	18	21	
BROWN - SAND + SMALL TO MED. GRAVEL	21	26	
BROWN - CEMENTED GRAVEL	26	28	
" - LARGE TO SMALL + SAND (PACKED)	28	44	
MED. GRAVEL + LOOSE SAND	44	63	
SMALL TO LARGE GRAVEL + SAND (PACKED)	63	72	
BROWN - CEMENTED GRAVEL	72	78	
BLACK - BASALT ROCK	78	86	
RED - ROCK	86	89	
BLACK - BASALT BROKEN	89	96	

Work started 2-1 — 1969 Completed 2-6 1969
Date well drilling machine moved off of well 2-10 1969

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Norman Randall Date 2-12, 1969
(Drilling Machine Operator)
Drilling Machine Operator's License No. 455

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME MILLER - ROBINSON + WEST
(Person, firm or corporation) (Type or print)
Address 5545 JOSEPH ST. S.E. SALEM
[Signed] Gordon R. Miller
(Water Well Contractor)
Contractor's License No. 37 Date 2-14, 1969

(USE ADDITIONAL SHEETS IF NECESSARY)