

RECEIVED

MAR... \$300

G-2070

JUL 10 1961

WATER WELL REPORT

State Well No. 6/3W-26 N

STATE ENGINEER SALEM, OREGON

STATE OF OREGON

State Permit No. 6

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

(1) OWNER: Name Nicolli W. Holoboff Address 7985 River Road N.E. Salem, Oregon

(2) LOCATION OF WELL: County Marion Owner's number, if any-- SW 1/4 SW 1/4 Section 26 T. 6S R. 3W W.M. Bearing and distance from section or subdivision corner 1300 ft. north & 1200 ft. east from S.W. corner of section 26, T.6 S., R. 3 W., of W.M. Well is located on Wheatland road. Approx. 1 1/4 mi. south of Clearlake Sch.

(3) TYPE OF WORK (check): New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ] If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check): Domestic [ ] Industrial [ ] Municipal [ ] Irrigation [X] Test Well [ ] Other [ ] (5) TYPE OF WELL: Rotary [ ] Driven [ ] Cable [X] Jetted [ ] Dug [ ] Bored [ ]

(6) CASING INSTALLED: Threaded [ ] Welded [X] 10" Diam. from 0 ft. to 117 ft. Gage .279

(7) PERFORATIONS: Perforated? [ ] Yes [X] No Type of perforator used Mills knife perforator. SIZE OF PERFORATIONS 3/8 in. by 2 in. 288 perforations from 98 ft. to 116 ft.

(8) SCREENS: Well screen installed [ ] Yes [X] No Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION: Was well gravel packed? [ ] Yes [X] No Size of gravel: 30 ft. Gravel placed from ft. to ft. Was a surface seal provided? [X] Yes [ ] No To what depth? 30 ft. Material used in seal- Puddled clay & sand. Did any strata contain unusable water? [ ] Yes [X] No Type of water? Depth of strata Method of sealing strata off

(10) WATER LEVELS: Static level 72 ft. below land surface Date 4/27/61 Artesian pressure lbs. per square inch Date

Log Accepted by: [Signed] Date 19

(11) WELL TESTS: Drawdown is amount water level is lowered below static level Was a pump test made? [X] Yes [ ] No If yes, by whom? Drillers Yield: 500 gal./min. with 20 ft. drawdown after 5 hrs. " 350 " 13 " 5 " " 200 " 7 " 5 " Bailer test XX gal./min. with XX ft. drawdown after XX hrs. Artesian flow g.p.m. Date Temperature of water 48 Was a chemical analysis made? [ ] Yes [X] No

(12) WELL LOG: Diameter of well 10 inches. Depth drilled 117 1/2 ft. Depth of completed well 117 1/2 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include Top soil-brown, Clay-yellow, Clay-light br. with fine sand, Clay-dark br., Conglomerate-medium-grey, Med. gravel & med. sand, gray, Med. gravel & sand, waterbearing, Sand-fine-gray, Med. conglomerate-waterbearing, Course gravel-loose-waterbrg., Med. conglomerate-waterbearing, Course gravel-loose-waterbrg.

Work started 4/12/ 1961. Completed 4/27/ 1961

(13) PUMP: Manufacturer's Name Type: H.P.

Well Driller's Statement: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. Stadel & Sons (Person, firm, or corporation) (Type or print) Address Rte. 3, Box 169, Silverton, Oregon

Driller's well number [Signed] R. Stadel (Well Driller) License No. 304 Date June 30, 1960

6/3W-26N

G-2070



# STADELI PUMP SERVICE

622 N. Water Street  
SILVERTON, OREGON



TR. 3-3671 or TR. 3-4841

Nicoli W. Holoboff  
7985 River Road  
Salem, Oregon

10'' well 117ft. deep

4/27/61 Well Test

500 gal. per min. at 92ft.
450 '' '' '' '' 89 ''
400 '' '' '' '' 87 ''
350 '' '' '' '' 85 ''
300 '' '' '' '' 83 ''
250 '' '' '' '' 81 ''
200 '' '' '' '' 79 ''

Standing level is 72 ft.

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

MARI.....

WATER WELL REPORT STATE ENGINEER STATE OF OREGON SALEM, OREGON

RECEIVED SEP - 7 1962

6/3W-26N

State Well No. ....

State Permit No. ....

(1) OWNER:

Name Nicole N. Hylaboff  
Address 7985 River Rd N.E. Salem, Oregon

(2) LOCATION OF WELL:

County Marion Owner's number, if any—  
1/4 1/4 Section T. R. W.M.

Bearing and distance from section or subdivision corner  
1300 ft. north 4/200 ft. east from S.W. corner of section 26, T. 6 S., R. 3 W. of W.M.

All is located on wheatland road APPROX. 1/4 mi. south of Clearlake Sch.

(3) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(5) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
Dug  Bored

(6) CASING INSTALLED:

Threaded  Welded   
10" Diam. from 0 ft. to 117 ft. Gage 279  
" Diam. from ..... ft. to ..... ft. Gage .....  
" Diam. from ..... ft. to ..... ft. Gage .....

(7) PERFORATIONS:

Perforated?  Yes  No  
Type of perforator used Wells Knife Perforator  
SIZE of perforations 3/8 in. by 3 in.  
228 perforations from 98 ft. to 116 ft.  
perforations from ..... ft. to ..... ft.  
perforations from ..... ft. to ..... ft.  
perforations from ..... ft. to ..... ft.  
perforations from ..... ft. to ..... ft.

(8) SCREENS:

Well screen installed  Yes  No  
Manufacturer's Name .....  
Type ..... Model No. ....  
Slot size ..... Set from ..... ft. to ..... ft.  
Diam. Slot size ..... Set from ..... ft. to ..... ft.

(9) CONSTRUCTION:

Was well gravel packed?  Yes  No Size of gravel: .....  
Gravel placed from ..... ft. to ..... ft.  
Was a surface seal provided?  Yes  No To what depth? 30 ft.  
Material used in seal Cuddled Clay & Sand  
Did any strata contain unusable water?  Yes  No  
Type of water? ..... Depth of strata .....  
Method of sealing strata off .....

(10) WATER LEVELS:

Static level 72 ft. below land surface Date 4/27/61  
Artesian pressure ..... lbs. per square inch Date .....

Log Accepted by:

[Signed] ..... Date ....., 19.....  
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom? Drillers  
Yield: 500 gal./min. with 20 ft. drawdown after 5 hrs.  
" 350 " 13 " 5 "  
" 200 " 7 " 5 "  
Bailer test  gal./min. with  ft. drawdown after  hrs.  
Artesian flow ..... g.p.m. Date .....  
Temperature of water 48 Was a chemical analysis made?  Yes  No

(12) WELL LOG:

Diameter of well 10 inches.  
Depth drilled 117 1/2 ft. Depth of completed well 117 1/2 ft.  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top soil - brown	0	2
Clay - yellow	2	10
Clay - light br. with fine sand	10	45
Clay - dark br.	45	70
Med. conglomerate - gray	70	78
Med. graded & med. sand gray	78	85
Med. gravel + sand (water bearing)	85	91
Sand - fine - gray	91	93
Med. conglomerate - water bearing	93	104
Course gravel loose - " "	104	106
Med. conglomerate - " "	106	115
Course gravel loose - " "	115	117 1/2

Work started 4/12 1962 Completed 4/27 1962

(13) PUMP:

Manufacturer's Name .....  
Type: ..... H.P. ....

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. Stadel & Sons  
(Person, firm, or corporation) (Type or print)

Address Rte 3, Box 169, Silverton, Oregon

Driller's well number .....

[Signed] Paul R. Stadel  
(Well Driller)

License No. 296 Date June 30, 1961