

RECEIVED well #1 MAR 28 1962 MART. 5305

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

STATE ENGINEER

WATER WELL REPORT

State Well No. 6/3W-27 F

STATE OF OREGON

G2271

State Permit No.

(1) OWNER:

Name Gordon Turnidge
Address Jefferson

(2) LOCATION OF WELL:

County MARION Owner's number, if any—
1/4 1/4 Section T. R. W.M.
Bearing and distance from section or subdivision corner
1540'S & 1300'F from NW
Corner DLC 69

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
10" Diam. from 1' ft. to 38' ft. Gage 2.50
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used Shets
SIZE of perforations 1/2 x 3/4 in. by 8 in.
42 perforations from ft. to ft.
perforations from 32' ft. to 38' ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed Yes No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Was a surface seal provided? Yes No To what depth? ft.
Material used in seal—
Did any strata contain unusable water? Yes No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 17 ft. below land surface Date 6-7-59
Artesian pressure lbs. per square inch Date

Log Accepted by:

[Signed] Date, 19.....
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? Driller
Yield: 600 gal./min. with 3 ft. drawdown after 3 hrs.
" " " " "
" " " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 57 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 10 inches.
Depth drilled 39 ft. Depth of completed well 39 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

| MATERIAL | FROM | TO |
|------------------------------|------|-----|
| Sandy loam | 0 | 6' |
| Sand & gravel | 6' | 16' |
| Spring Kies of Sand & gravel | 16' | 39' |

Work started 6-2 1959 Completed 6-7 1959

(13) PUMP:

Manufacturer's Name
Type: H.P.

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Bill Hamilton Drilling Co
(Person, firm, or corporation) (Type or print)

Address 838 E 3rd Ave Albany

Driller's well number

[Signed] Bill Hamilton
(Well Driller)

License No. 52 Date 6-14 1959