

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

WATER WELL REPORT

RECEIVED

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

STATE OF OREGON AUG 28 1975

State Well No. 45/1w-15

WATER RESOURCES DEPT. (Please type on this side)
SALEM, OREGON State Permit No.

53
MARI...
card in July

(1) OWNER:

Name Byron & Warren Grinn
Address R.F.D. 3 Box 787
Marion Ore.

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
8" Diam. from 0 ft. to 105 ft. Gage 250
" Diam. from " ft. to " ft. Gage
" Diam. from " ft. to " ft. Gage

PERFORATIONS:

Perforated? Yes No.
Type of perforator used STOR
Size of perforations 3/8 in. by 1 1/2 in.
300 perforations from 85 ft. to 102 ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from " ft. to " ft.
Diam. Slot size Set from " ft. to " ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? Driller
Yield: 140 gal./min. with 55 ft. drawdown after 12 hrs.
" " " " " "
" " " " " "
Bailer test gal./min. with " ft. drawdown after " hrs.
Artesian flow g.p.m.
Temperature of water 53 Depth artesian flow encountered " ft.

(9) CONSTRUCTION:

Well seal—Material used Cement & Bentonite
Well sealed from land surface to 60 ft.
Diameter of well bore to bottom of seal 12 3/4 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 2 Yrds sacks
Number of sacks of bentonite used in well seal 5 sacks
Brand name of bentonite NATION 21
Number of pounds of bentonite per 100 gallons
of water " lbs./100 gals.
Was a drive shoe used? Yes No Plugs " Size: location " ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel: "
Gravel placed from " ft. to " ft.

(10) LOCATION OF WELL:

County Marion Driller's well number
SW 1/4 SE 1/4 Section 15 T. 45 R. 1 W W.M.
Bearing and distance from section or subdivision corner
In The Park.

(11) WATER LEVEL: Completed well.

Depth at which water was first found 68 ft.
Static level 39 ft. below land surface. Date 8-5-75
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing "
Depth drilled 105 ft. Depth of completed well 105 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top Soil	0	2	
Dark Clay	2	18	
Silt Clay	18	32	
Blue Clay	32	68	39
Cement Gravel	68	82	39
Sand & Gravel	82	102	39
Green Clay	102	105	

Well drilled under Plans & Specs set forth by Batewright Engineering as a public water supply.

Work started 7-28 1975 Completed 8-5 1975
Date well drilling machine moved off of well 8-5 1975

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] John W Beck Date 8-6, 1975
(Drilling Machine Operator)

Drilling Machine Operator's License No. 437

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name John W Beck Well Drilling
(Person, firm or corporation) (Type or print)

Address 24137 S Kylan Dr Canby Ore.

[Signed] John W Beck
(Water Well Contractor)

Contractor's License No. 449 Date 8-6, 1975