

RECEIVED  
JUN 24 1957

WATER WELL REPORT 5349

STATE OF OREGON

MARION

State Well No. 6/3W-28M(2)  
State Permit No. G 544

**(1) OWNER:** STATE ENGINEER

Name Mr. B.E. Stratton  
Address Route 2, Box 55  
Salem, Oregon

**(2) LOCATION OF WELL:** 3

County Marion Owner's number, if any—  
NW ¼ SW ¼ Section 28 T. 6 S. R. 3 W. W.M.  
Bearing and distance from section or subdivision corner  
2547.7 ft. North and 436.9 ft. East  
from the SW. corner of Section 28,  
T.6 S., R.3 West. in Marion County, Oregon

**TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 11.

**(4) PROPOSED USE (check):** **(5) TYPE OF WELL:**

Domestic  Industrial  Municipal  Rotary  Driven   
Irrigation  Test Well  Other  Cable  Jetted   
Dug  Bored

**(6) CASING INSTALLED:** Threaded  Welded   
12" Diam. from Top ft. to 28 ft. Gage # 406  
" Diam. from \_\_\_\_\_ ft. to 28 ft. Gage \_\_\_\_\_  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

**(7) PERFORATIONS:** Perforated?  Yes  No  
Type of perforator used Acet. Torch  
SIZE of perforations 1/2 in. by 6 in.  
120 perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
120 perforations from 17 ft. to 27 ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(8) SCREENS:** Well screen installed  Yes  No  
Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(9) CONSTRUCTION:**  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Was a surface seal provided?  Yes  No To what depth? \_\_\_\_\_ ft.  
Material used in seal—  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ Depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_

**(10) WATER LEVELS:**  
Static level 4 1/2 ft. below land surface Date 6/4/57  
Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

Log Accepted by: \_\_\_\_\_  
[Signed] Byron E. Stratton Date June 10, 1957  
(Owner)

**(11) WELL TESTS:** Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom?  
Yield: gal./min. with ft. drawdown after hrs.  
" " " " " "  
" " " " " "  
" " " " " "  
Bailer test gal./min. with ft. drawdown after hrs.  
Artesian flow g.p.m. Date  
Temperature of water 57 Was a chemical analysis made?  Yes  No

**(12) WELL LOG:** Diameter of well 12 inches.  
Depth drilled 28 ft. Depth of completed well 28 ft.  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
<u>Sandy Loam</u>	<u>0</u>	<u>7</u>
<u>Brown Sand &amp; Gravel</u>	<u>7</u>	<u>28</u>

Work started May 29 1957. Completed June 4 1957

**(13) PUMP:** Manufacturer's Name \_\_\_\_\_  
Type: \_\_\_\_\_ H.P. \_\_\_\_\_

**Well Driller's Statement:**  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Max Wymore  
(Person, firm, or corporation) (Type or print)  
Address Rt. 2 Salem, Oregon  
Driller's well number 845  
[Signed] Max Wymore (Well Driller)  
License No. 24 Date June 5, 1957