

ORIGINAL  
File Original and  
Duplicate with the  
STATE ENGINEER  
SALEM, OREGON

**RECEIVED**  
JUN 15 1956

# WATER WELL DRILLERS REPORT

STATE OF OREGON

Do Not  
Fill In

State Well No. 93W-28 P11  
State Permit No. 629

(1) OWNER: STATE ENGINEER  
Name: D. A. KENNEDY, MAR 21 5352  
Address: ROUTE 1 INDEPENDENCE  
ORE.

(2) LOCATION OF WELL:  
County: MARION Owner's number, if any— 6 355  
R. F. D. or Street No. \_\_\_\_\_  
Bearing and distance from section or subdivision corner  
1310' N 4 657' E of SW Corner  
SE 1/4 SW 1/4 Sec 28 T65 R 3 W.

(3) TYPE OF WORK (check):  
New well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):  
Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(5) EQUIPMENT:  
Rotary   
Cable   
Dug Well

(6) CASING INSTALLED:  
Threaded  Welded

FROM	ft. to	ft.	Diam.	Gage or Wall
"	1"	45"	"	"
"	"	"	"	"
"	"	"	"	"
"	"	"	"	"
"	"	"	"	"

If gravel packed

Diameter of Bore	from ft.	to ft.
"	"	"
NONE	"	"
"	"	"
"	"	"
"	"	"

Type and size of shoe or well ring 12" steel Size of gravel:  
Describe joint WELDED

(7) PERFORATIONS:  
Type of perforator used MILLS TYPE

SIZE of perforations	ft. to	ft.	in., length, by	perf per foot	No. of rows
"	18'	28'	3" 10"	24	" "
"	40'	43'	3" 10"	3	" "
"	"	"	"	"	" "
"	"	"	"	"	" "

SCREENS:  
Give Manufacturer's Name, Model No. and Size NONE

(8) CONSTRUCTION:  
Was a surface sanitary seal provided?  Yes  No To what depth 6" ft.

Were any strata sealed against pollution?  Yes  No.  
If yes, note depth of strata  
FROM 1' ft. to 18' ft.

METHOD OF SEALING BACK FILL

(9) WATER LEVELS:  
Depth at which water was first found 18' ft.  
Standing level before perforating 16' ft.  
Standing level after perforating 16' ft.

Log Accepted by: D. A. Kennedy  
[Signed] D. A. Kennedy Dated June 12, 1956  
Owner

(10) WELL TESTS:  
Was a pump test made?  Yes  No If yes, by whom? STETTLER SUPPLY  
Yield: 550 gal./min. with 2' ft. draw down after 6 hrs.  
" " " " " "  
" " " " " "  
Artesian flow \_\_\_\_\_ g.p.m.  
Shut-in pressure \_\_\_\_\_ lbs. per square inch.  
Baller test \_\_\_\_\_ g.p.m. with \_\_\_\_\_ ft. drawdown  
Temperature of water 55° Was a chemical analysis made?  Yes  No  
Was electric log made of well?  Yes  No

(11) WELL LOG:

Diameter of well, 12" 1-0 inches.  
Total depth 45' ft. Depth of completed well 45' ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

ft. to	ft.	Formation
7"	7'	TOPSOIL
10"	27'	CEMENT GRAVEL
1"	28'	WATER GRAVEL # 4-
10"	38'	MUCKY SAND
6"	38'6"	WATER GRAVEL
6'6"	45'	CEMENT GRAVEL
"	"	"
"	"	"
"	"	"
"	"	"
"	"	"
"	"	"
"	"	"
"	"	"
"	"	"
"	"	"
"	"	"
"	"	"
"	"	"
"	"	"
"	"	"
"	"	"
"	"	"
"	"	"
"	"	"
"	"	"
"	"	"
"	"	"
"	"	"
"	"	"
"	"	"

Ground elevation at well site \_\_\_\_\_ feet above mean sea level.  
Work started 5-9-1956 Completed 5-10-1956

Well Driller's Statement:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J. A. SNEED + SONS  
(Person, firm, or corporation) (Typed or printed)

Address 2505 BROOKS ST SALEM.

Driller's well number \_\_\_\_\_

[Signed] J. A. Sneed  
(Well Driller)

License No. 6- Dated 6-7-1956