

WATER WELL REPORT

State Well No. 6/3W-34bd

STATE OF OREGON G 5136

State Permit No. _____

MAF 5364

(1) OWNER: Philip J Blake
 Name PHILIP J BLAKE WEATHERS
 Address 172 FOX ST
WILM ORE.

(2) LOCATION OF WELL:
 County MARION Owner's number, if any—
 1/4 1/4 Section T. R. W.M.
 Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check): OLD WELL
 No Well Deepening Reconditioning Abandon
 Abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check): Domestic Industrial Municipal
 Irrigation Test Well Other
 (5) TYPE OF WELL: Rotary Driven
 Cable Jetted
 Dug Bored

(6) CASING INSTALLED: Threaded Welded
8" Diam. from 1 ft. to 40 ft. Gage 4"
 " Diam. from _____ ft. to _____ ft. Gage _____
 " Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS: Perforated? Yes No
 Type of perforator used HILLS TYPE
 SIZE of perforations in. by _____ in.
3/8" perforations from 23' ft. to 38' ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.

(8) SCREENS: Well screen installed Yes No
 Manufacturer's Name _____ Model No. _____
 _____ Slot size _____ Set from _____ ft. to _____ ft.
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION: Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.
 Was a surface seal provided? Yes No To what depth? 6" IT ft.
 Material used in seal— DOZED
 Did any strata contain unusable water? Yes No
 Type of water? SANDY Depth of strata 18"
 Method of sealing strata off PLASTER + BRICK FILL

(10) WATER LEVELS:
 Static level 16' ft. below land surface Date 1-11-55
 Artesian pressure _____ lbs. per square inch Date _____

Log Accepted by: _____
 [Signed] _____ Date _____, 19____
 (Owner)

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom? STEELE SUPPLY
 Yield: 600 gal./min. with 4 ft. drawdown after 2 hrs.
 " " " " " "
 " " " " " "
 Bailer test gal./min. with _____ ft. drawdown after _____ hrs.
 Artesian flow _____ g.p.m. Date _____
 Temperature of water 55 Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well 8"-0 inches.
 Depth drilled 40' ft. Depth of completed well 40' ft.
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
<u>SILT</u>	<u>3</u>	<u>5</u>
<u>SILT YELLOW COLOR</u>	<u>15</u>	<u>16</u>
<u>CEMENTED GRAVEL 4"</u>	<u>2</u>	<u>20</u>
<u>GRAVEL 4"</u>	<u>7</u>	<u>27</u>
<u>CEMENTED GRAVEL</u>	<u>10</u>	<u>37</u>
<u>GRAVEL 2"</u>	<u>3</u>	<u>40</u>

Work started JAN 11 1955 Completed JAN 13 1955

(13) PUMP: Manufacturer's Name CUMMINS
 Type: CENTRIFUGAL H.P. 20HP

Well Driller's Statement:
 This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J. A. SNEED & SONS (Person, firm, or corporation) (Type or print)
 Address 2505 BRICKS ST SALEM O.

Driller's well number _____
 [Signed] _____ (Well Driller)
 License No. _____ Date 1-11-55, 19____