

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

WATER WELL REPORT

STATE OF OREGON

JUL 26 1973

State Well No.

65/3W-34

(Please type or print)

STATE ENGINEER

(Do not write above this line)

SALEM OREGON

State Permit No.

STATE ENGINEER, SALEM, OREGON, 97301
within 30 days from the date
of well completion.

(1) OWNER:

Name M'NARY OAKS TRAILER VILLA
Address 5355 RIVER ROAD NORTH
SALEM ORE.

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Cable Dug

Driven Jetted Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded

8" Diam. from +2 ft. to 130 ft. Gage # 277
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(6) PERFORATIONS:

Perforated? Yes No.

Type of perforator used STAR
Size of perforations 3/8 in. by 1/4 in.
300 perforations from 8.5 ft. to 95 ft.
300 perforations from 110 ft. to 125 ft.
_____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? STRASSER
Yield: 410 gal./min. with 34 ft. drawdown after 24 hrs.
" " " "
" " " "
Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m.
Temperature of water 54° Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Well seal—Material used CEMENT GROUT
Well sealed from land surface to 30 ft. ft.
Diameter of well bore to bottom of seal 12 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 25 sacks
Number of sacks of bentonite used in well seal _____ sacks
Brand name of bentonite _____
Number of pounds of bentonite per 100 gallons _____
of water _____ lbs./100 gals.
Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County MARION Driller's well number 5448
NE 1/4 SE 1/4 Section 34 T. 65 R. 3W W.M.
Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.

Depth at which water was first found 85 ft.
Static level 30 ft. below land surface. Date 7/17/73
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing _____
Depth drilled 130 ft. Depth of completed well 130 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
TOP SOIL	0	3	
BROWN SANDY CLAY	3	18	
CLAY AND GRAVEL	18	50	
CEMENTED GRAVEL	50	85	
SAND AND GRAVEL (WATER)	85	95	
SAND GRAVEL AND CLAY	95	105	
CEMENTED GRAVEL	105	110	
SAND AND GRAVEL (WATER)	110	125	
CEMENTED GRAVEL	125	130	

Work started JULY 2 1973 Completed JULY 20 1973
Date well drilling machine moved off of well JULY 20 1973

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Wm E Smith Date 7/23, 1973
(Drilling Machine Operator)

Drilling Machine Operator's License No. 175

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name R. STRASSER DRILLING CO
(Person, firm or corporation) (Type or print)

Address 8110 SE SUNSET LANE PORTLAND ORE.

[Signed] Robert L Strasser
(Water Well Contractor)

Contractor's License No. 10 Date JULY 23, 1973