

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy of this report  
are to be filed with the

WATER RESOURCES DEPARTMENT  
SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

**WATER WELL REPORT**

STATE OF OREGON

(Please type or print)

(Do not write above this line)

RECEIVED

State Well No.

65/1E-6dc

MAY 1 1978

State Permit No.

WATER RESOURCES DEPT

**(1) OWNER:**

Name Arie Jongeneel  
Address Rt. 1 Box 29  
Mt. Angel, Oregon 97362

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon

If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**

Rotary  Driven   
Cable  Jetted   
Dug  Bored

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

**CASING INSTALLED:**

8" Diam. from 0 ft. to 278 ft. Gage .25  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

**PERFORATIONS:**

Perforated?  Yes  No.

Type of perforator used torch  
Size of perforations 3/16 in. by 12 in.  
504 perforations from 134 ft. to 277 ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

**(7) SCREENS:**

Well screen installed?  Yes  No

Manufacturer's Name  
Type Model No.  
Diam. Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

**(8) WELL TESTS:**

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom? driller  
Yield: 250 gal./min. with 220 ft. drawdown after 1 hrs.  
140 " 140 " 1 "  
" " " " "  
Bailer test gal./min. with ft. drawdown after hrs.  
Artesian flow g.p.m.  
Temperature of water Depth artesian flow encountered ft.

**(9) CONSTRUCTION:**

Well seal—Material used Cement  
Well sealed from land surface to 26 ft.  
Diameter of well bore to bottom of seal 15 in.  
Diameter of well bore below seal 15 in.  
Number of sacks of cement used in well seal 30 sacks  
How was cement grout placed? temeie pipe

Was a drive shoe used?  Yes  No Plugs Size: location ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? depth of strata  
Method of sealing strata off  
Was well gravel packed?  Yes  No Size of gravel: 1/8x1/4  
Gravel placed from 26 ft. to 278 ft.

**(10) LOCATION OF WELL:**

County Marion Driller's well number 8  
SW 1/4 SE 1/4 Section 6 T. 6S R. 1E W.M.  
Bearing and distance from section or subdivision corner

**(11) WATER LEVEL: Completed well.**

Depth at which water was first found 30 ft.  
Static level 40 ft. below land surface. Date 4-7-78  
Artesian pressure lbs. per square inch. Date

**(12) WELL LOG:**

Diameter of well below casing 0

Depth drilled 286 ft. Depth of completed well 278 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
topsoil	0	2	
clay brown	2	16	
cemented gravel	16	36	16
clay brown/ layers of sand	36	50	
clay grey	50	60	
clay & sand & gravel	60	67	
gravel & grey clay	67	85	
some wood in clay green	85	172	
clay w/layers sand gravel	172	250	
lost circulation	250	275	
large gravel	275	286	40

Work started 3-26 19 78 Completed 4-7 19 78  
Date well drilling machine moved off of well 4-7 19 78

**Drilling Machine Operator's Certification:**

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] E. Skyles Date 4-20, 19 78  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 271

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Skyles Drilling & Supply, Inc.  
(Person, firm or corporation) (Type or print)

Address 1169 Molalla Ave. Oregon City, Or.

[Signed] Martin D. Skyles  
(Water Well Contractor)

Contractor's License No. 553 Date 4-20, 19 78