

WATER WELL REPORT

RECEIVED App 1 G-12091

NOTICE TO WATER WELL CONTRACTOR: The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

STATE OF OREGON AUG 12 1975 State Well No. 651E-12

WATER RESOURCES DEPT SALEM, OREGON State Permit No.

5583 MARI... RECEIVED

JUN 10 1991

(1) OWNER: Name Richard Hammelman Address Rte. 1, Box 112-A Mt. Angel, Oregon 97362

(10) LOCATION OF WELL: County Marion Driller's well number N.E. 1/4 S.E. 1/4 Section 12 T.6 S. R. 1 E. W.M. Bearing and distance from section or subdivision corner

(2) TYPE OF WORK (check): New Well [x] Deepening [] Reconditioning [] Abandon []

(3) TYPE OF WELL: Rotary [x] Driven [] Cable [x] Jetted [] Dug [] Bored [] (4) PROPOSED USE (check): Domestic [x] Industrial [] Municipal [] Irrigation [x] Test Well [] Other []

(11) WATER LEVEL: Completed well. Depth at which water was first found 261 ft. Static level 100 ft. below land surface. Date 1975

CASING INSTALLED: 10" Diam. from 1+ ft. to 72 ft. Gage 250

(12) WELL LOG: Diameter of well below casing 8" Depth drilled 408 ft. Depth of completed well 408 ft.

PERFORATIONS: Type of perforator used Factory -preperforated Size of perforations 3/16 in. by 3 in.

Table with columns: MATERIAL, From, To, SWL. Rows include: Top -Soil, brn., Clay-brn., Course conglom., with boulders- Boulders with some clay-, Course-conglom.,-gray-, Clay-brn., Clay-grey-, Clay-brn., Clay-grey-, Clay-blue-, Med. conglom., brn., Basalt-grey, hard., Claystone-grey-sticky-, Basalt-grey-hard-, Basalt-weathered-brn., - (W.B.), Basalt-grey-hard-, Basalt-grey-porous- (W.B.), Basalt-grey-hard-

(7) SCREENS: Well screen installed? [] Yes [x] No Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level Was a pump test made? [] Yes [x] No Yield: gal./min. with ft. drawdown after hrs.

(9) CONSTRUCTION: Well seal-Material used Cement Well sealed from land surface to 24 ft. Diameter of well bore to bottom of seal 14 in. Diameter of well bore below seal 10 in. Number of sacks of cement used in well seal 12 1/2 sacks

Work started 5/2/75 19 Completed 6/3/75 19 Date well drilling machine moved off of well 6/3/75 19

Drilling Machine Operator's Certification: This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief. [Signed] Burr Rambo Date 6-14, 1975

Water Well Contractor's Certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Name R. Stadel & Sons, Inc. Address Rte. 3, Box 169, Silverton, Oregon, Inc. [Signed] Paul R. Stadel Date June 14, 75