

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

RECEIVED MAR 26 34
 SEP 17 1962
 WATER WELL REPORT
 STATE OF OREGON
 (Please type or print)

State Well No. 6/1-18
 State Permit No.

(1) OWNER:

Name PAUL DICKMAN
 Address ROUTE ONE SILVERTON

(2) LOCATION OF WELL:

County MARION Driller's well number
 1/4 Section 18 T. 6.S. R. 1.E. W.M.
 Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well Deepening Reconditioning Abandon
 abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Rotary Driven
 Irrigation Test Well Other Cable Jetted
 Dug Bored

(5) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(6) CASING INSTALLED:

Threaded Welded
 8" Diam. from NONE ft. to ft. Gage
 6" Diam. from 128 ft. to 197 ft. Gage 1202
 " Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No
 Type of perforator used
 Size of perforations in. by in.
 perforations from ft. to ft.
 perforations from ft. to ft.
 perforations from ft. to ft.
 perforations from ft. to ft.
 perforations from ft. to ft.

(8) SCREENS:

Well screen installed Yes No
 Manufacturer's Name Model No.
 Slot size Set from ft. to ft.
 Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

WELL DRILLED TO 77' 14 YEARS AGO
 Well seal—Material used in seal
 Depth of seal ft. Was a packer used? NOTHING
 Diameter of well bore to bottom of seal in. KNOWN
 Were any loose strata cemented off? Yes No Depth ABOUT
 Was a drive shoe used? Yes No SEALS
 Was well gravel packed? Yes No Size of gravel:
 Gravel placed from ft. to ft.
 Did any strata contain unusable water? Yes No
 Type of water? Depth of strata
 Method of sealing strata off

(10) WATER LEVELS:

Static level 13 ft. below land surface Date 8/23/62
 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom?
 Yield: gal./min. with ft. drawdown after hrs.
 CUSTOMER PUT ORIGINAL TRACTOR
 DRIVEN TURBINE BACK IN
 Bailer test 40 gal./min. with 10 ft. drawdown after 1 hrs.
 Artesian flow g.p.m. Date
 Temperature of water 57 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 6"
 Depth drilled 257 ft. Depth of completed well 257 ft.
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
MED. HARD PINK AND GREY BASALT	77	142
BROWN SOFT ROCK COAL LIKE	142	146
GREY CLAY WITH BRITTLE CHUNKS	146	152
YELLOW SILTY CLAY	152	170
MED GREY BASALT	170	197
END OF 8" HOLE AS IT IS SAYING	197	
VERY HARD GREY FINE GRAINED BASALT	197	218
SOFTER COURSE GRAINED PINKISH GREY	218	250
VERY HARD GREY BASALT	250	257
ORIGINAL STATIC	17'	JULY 27, 62
AFTER REDRILLING	13'	AUG 23, 62

Work started JULY 27 19 62 Completed AUG 23 19 62
 Date well drilling machine moved off of well AUG 23 19

(13) PUMP:

Manufacturer's Name BERKELY
 Type: TURBINE H.P. UNKNOWN

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLIAM J. STENNETT
 (Person, firm or corporation) (Type or print)

Address 361 WARNER MILNE RD DRE CITY

Drilling Machine Operator's License No. 170

[Signed] William J. Stennett
 (Water Well Contractor)

Contractor's License No. 5 Date Sept 5, 19 62