

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date of well completion.

JAN 22 1970 STATE OF OREGON

(Please type or print)

(Do not write above this line)

STATE ENGINEER SALEM, OREGON

MARI... 566
6-9394

State Well No. 4/1W-17

State Permit No.

(1) OWNER:

Name HENRY GOOD
Address Box 362 DONALD, OREGON

(2) TYPE OF WORK (check):

New Well [x] Deepening [] Reconditioning [] Abandon []

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [] Driven []
Cable [x] Jetted []
Dug [] Bored []

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal []
Irrigation [x] Test Well [] Other []

CASING INSTALLED:

8" Diam. from 70 ft. to 108 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? [] Yes [x] No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? [] Yes [x] No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 35 ft. below land surface Date 12/29/69
Man pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? [x] Yes [] No If yes, by whom? DRILLER
Yield: 150 gal./min. with 35 ft. drawdown after 1 hrs.
" " " " " "
" " " " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 54° Was a chemical analysis made? [] Yes [x] No

(10) CONSTRUCTION:

Well seal—Material used BENTONITE CLAY
Depth of seal 40 ft.
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? [] Yes [x] No Depth
Was a drive shoe used? [x] Yes [] No
Did any strata contain unusable water? [] Yes [x] No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? [] Yes [x] No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County MARION Driller's well number 26
1/4 1/4 Section 17 T. 45 R. 1W W.M.
Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 8
Depth drilled 111 ft. Depth of completed well 111 ft.

Formation; Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
BROWN TOP SOIL	0	1	
BROWN CLAY	1	42	
BROWN SAND	42	55	
BROWN CLAY	55	67	
BLUE CLAY	67	95	
BROWN CLAY	95	98	
BLUE CLAY	98	109	
BLACK SAND + FINE GRAVEL	109	111	

Work started 12-20 1969 Completed 12-29 1969

Date well drilling machine moved off of well 12-29 1969

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] William D Christenson Date 12/29, 1969
(Drilling Machine Operator)

Drilling Machine Operator's License No. 500

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME William D Christenson
(Person, firm or corporation) (Type or print)

Address P.O. Box 343 Hubbard, ORE

[Signed] William D Christenson
(Water Well Contractor)

Contractor's License No. 511 Date 12/29, 1969