NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER RESOURCES DEPARTMENT: SALEM, OREGON 97310 within 30 days from the dates of well completion.

WATER WELL REPORT

STATE OF OREGON

Place type or print)
(Do not write shows this line)

State Well No. 65/1E-22	
State Permit No.	

JINO		
(1) OWNER: WATER RI	(10) LOCATION OF WELL:	
Name City of Scotts Mills	County Marion Driller's well number	
Address Scotts Mills, Oregon 97375 ALE III.	برين بريد بريد بريد بريد بريد بريد بريد بريد	
(2) TYPE OF WORK (check):	Bearing and distance from section or subdivision corner Approx.2115 Ft.W.& 825 ft. S. of N.E. cor.of	
New Well □ Deepening □ Reconditioning ☐ Abandon □	Sec.22.T.6 SR.1 E. of W.M.	
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 50 -orig. ft.	
Rotary Driven Domestic Industrial Municipal X	Static level 63 ft. below land surface. Date 6/13/78	
Dug Bored Irrigation Test Well Other	Artesian pressure XX lbs. per square inch. Date	
CASING INSTALLED: Threaded Welded To	(12) WELL LOG: Diameter of well below casing	
"Diam. from ft. to ft. Gage ft. Gage ft. Gage ft. Gage ft. Gage ft. Gage	Depth drilled 0 ft. Depth of completed well 212 ft.	
"Diam. from ft. to ft. Gage ft. Gage ft. Gage ft. Gage ft. Gage	Formation: Describe color, texture, grain size and structure of materials;	
PERFORATIONS: Perforated? ≯ Yes ☐ No.	and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.	
Type of perforator used OrigMills Knife	MATERIAL From To SWL	
Size of perforations in. by 3 in.		
48 perforations from 38 ft. to 50 ft.		
perforations from ft. to ft.		
perforations fromft. toft.		
(7) SCREENS: Well screen installed? ☐ Yes 🕱 No		
Manufacturer's Name		
Type Model No.	We made a bailer test before putting in	
Diam. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.	a cid and it made 5 gpm.after approx. # 1½ hrs. We used 23 gals.of LBA.which	
Diam, Stot size Set from 11. to	means Liquid Antibacterial Acid. Which	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	is a liquid non-volatile, organic acid.	
Was a pump test made? ▼ Yes □ No If yes, by whom? Drillers		
Yield: 7.2 -aftarmacida 137 ft. drawdown after 4 hrs.	We pumped approx. 30 gpm. for 22 mins.	
" " "	and then it pumped 7½ gpm. from 200 ft.	
,, ,, ,, ,, ,, ,, ,, ,, ,, ,, ,, ,, ,,	after acidizing the well. An increase	
efore acid- Bailer test 5 gal./min. with 145 ft. drawdown after 1½ hrs.	of 2½ gpm.	
Artesian flow g.p.m.		
Terature of water Depth artesian flow encountered ft.	Work started 6/13/78 19 Completed 6/21/78 19	
(9) CONSTRUCTION:	Date well drilling machine moved off of well 6/21/78 19	
Well seal-Material used Orig. Cement	Drilling Machine Operator's Certification:	
Well sealed from land surface to ft.	This well was constructed under my direct supervision. Materials used and information reported above are true to my	
Diameter of well bore to bottom of seal in.	best knowledge and belief	
Diameter of well bore below seal	[Signed] Faul J. Stadeli Date 6-26, 1978	
Number of sacks of cement used in well seal sacks	(Drilling Machine Operator) 16	
How was cement grout placed? Gravity Pressure	Drilling Machine Operator's License No.	
1	Water Well Contractor's Certification:	
111111111111111111111111111111111111111	This well was drilled under my jurisdiction and this report is	
Was a drive shoe used? Two Two Diver Size leastion	true to the best of my knowledge and belief.	
Was a drive shoe used? ☐ Yes ☐ No Plugs Size: location ft. Did any strata contain unusable water? ☐ Yes ☐ No	Name R.Stadeli & Sons, Inc. (Person, firm or corporation) (Type or print)	
	Address 11364 Evrgrn. Rd. N. E Silvrtn. Qr. 97381	
Type of water? depth of strata	AUGU COO - II J.	
Method of sealing strata off	[Signed] Gaul S. Staleli	
Was well gravel packed? □XYes □ No Size of gravel: 3/4 rd.	(Water Well Contractor)	
Gravel placed from 92 ft. to 20 ft.	Contractor's License No296 Date	