

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

RECEIVED
JUL 1 1965
STATE ENGINEER

MAR 11 1965 5332

WATER WELL REPORT

State Well No. 6/1-22 B
State Permit No. _____

(1) OWNER: SALEM OREGON
Name City of Scotts Mills
Address C/O Mrs. Ann Sorenson

(2) LOCATION OF WELL:
County Marion Driller's well number _____
Bearing and distance from section or subdivision corner
2115ft W & 825 ft S of N.E. cor. of sec 22 T. 6S R 1E of WM

(3) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic Industrial Municipal Irrigation Test Well Other
(5) TYPE OF WELL:
Rotary Driven Cable Jetted Dug Bored

(6) CASING INSTALLED: Threaded Welded
8" Diam. from 0 ft. to 92 ft. Gage 250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS: Perforated? Yes No
Type of perforator used Mills
Size of perforations 1/8 in. by 2 in.
48 perforations from 38 ft. to 50 ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS: Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:
Well seal—Material used in seal cement
Depth of seal 20 ft. Was a packer used? yes
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: 3/4 round
Gravel placed from 92 ft. to 20 ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:
Static level 110 ft. below land surface Date 5/10/65
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? driller
Yield: 30 gal./min. with 90 ft. drawdown after 6 hrs.
" " " " " "
" " " " " "
Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well below casing 8"
Depth drilled 212 ft. Depth of completed well 212 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top Soil	0	1
Clay brn.	1	35
Decomposed rock brn.	35	52
Hard boulder brn.	52	55
Soft claystone grey	55	72
Coal seam blk.	72	85
Hard basalt blk	85	212
Approx 5gpm coming at rest from	50	180

Work started 3/15 1965 Completed 5/11 1965
Date well drilling machine moved off of well 5/11 1965

(13) PUMP:
Manufacturer's Name _____
Type: _____ H.P. _____

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME R Stadel & Sons (Type or print)
Address Rt 3 Box 169, Silverton, Oreg
Drilling Machine Operator's License No. 84
[Signed] Paul R. Stadel
Contractor's License No. 296 Date 5/18 1965