

MAR 5983 RECEIVED

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy  
of this report shall be  
filed with the  
STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

WATER WELL REPORT OCT 16 1968  
Well No. 7/14-2  
STATE ENGINEER SALEM, OREGON

(1) OWNER: SALEM OREGON  
Name M.L. Klack Klaxton  
Address 1327 S. Water, Silverton, Oregon

(2) LOCATION OF WELL:  
County Marion Driller's well number \_\_\_\_\_  
1/4 Section T. R. W.M.  
Bearing and distance from section or subdivision corner  
1375 ft. N. & 5 ft. W. of S.E. corner of sec.  
2 T. 7 S., R. 1 W.

(3) TYPE OF WORK (check):  
New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):  
Domestic  Industrial  Municipal   
Irrigation  Test Well  Other   
(5) TYPE OF WELL:  
Rotary  Driven   
Cable  Jetted   
Dug  Bored

(6) CASING INSTALLED:  
Threaded  Welded   
8 " Diam. from 0 ft. to 19 ft. Gage .250

(7) PERFORATIONS:  
Perforated?  Yes  No  
Type of perforator used \_\_\_\_\_  
Size of perforations in. by in.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) SCREENS:  
Well screen installed?  Yes  No  
Manufacturer's Name \_\_\_\_\_  
Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(9) CONSTRUCTION:  
Well seal—Material used in seal Bentonite  
Depth of seal 19 ft. Was a packer used? no  
Diameter of well bore to bottom of seal 12-4" to 18" & 9-5/8"  
to 19"  
Were any loose strata cemented off?  Yes  No Depth \_\_\_\_\_  
Was a drive shoe used?  Yes  No  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Did any strata contain unusuable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_

(10) WATER LEVELS:  
Static level 13 ft. below land surface Date 6/20/68  
Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

(11) WELL TESTS: Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom?  
Yield: gal./min. with ft. drawdown after hrs.

" Air \_\_\_\_\_ " " " "  
~~Water test~~ 7 gal./min. with 185 ft. drawdown after 1 hr.  
Artesian flow \_\_\_\_\_ g.p.m. Date \_\_\_\_\_  
Temperature of water XX Was a chemical analysis made?  Yes  No

(12) WELL LOG: Diameter of well below casing 7-7/8"  
Depth drilled ~~200~~ 215 ft. Depth of completed well 215 ft.  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top soil-red	0	1
Clay & boulders-brown	1	10
Claystone-grey-hard	10	80
5 gpm. water at 80 ft.		
Sandstone-hd., light grey	80	145
Claystone-grey-hd.	145	215
Total of 7 gpm. at 200 ft.		

Work started 6/20/68 19 \_\_\_\_\_ Completed 6/20/68 19  
Date well drilling machine moved off of well 6/20/68 19

(13) PUMP:  
Manufacturer's Name unknown  
Type: \_\_\_\_\_ H.P. \_\_\_\_\_

Water Well Contractor's Certification:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
NAME R. Stadel & Sons  
(Person, firm or corporation) (Type or print)  
Address Rte. 3, Box 169, Silverton, Oregon  
Drilling Machine Operator's License No. 84  
[Signed] Paul R. Stadel  
(Water Well Contractor)  
Contractor's License No. 296 Date 8/12/68, 19\_\_\_\_\_