

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

WATER WELL REPORT

STATE OF OREGON

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date

of well completion

(Please type or print)

(Do not write above this line)

State Well No. 7/16-2 J

State Permit No.

SILVERTON TRAILER & OVERT.

(1) OWNER:

Name C.O. BULLOCK BEAS.
Address 4733 SILVERTON RD. N.E. SALEM, ORE

(2) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon []
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [X] Driven []
Cable [] Jetted []
Dug [] Bored []

(4) PROPOSED USE (check):

Domestic [X] Industrial [] Municipal [X]
Irrigation [] Test Well [] Other []

CASING INSTALLED:

8" Diam. from 0 ft. to 21 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? [] Yes [X] No

Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? [] Yes [X] No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 14 ft. below land surface Date 9/15/67
Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [] Yes [X] No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
Ball test 60 gal./min. with 51 ft. drawdown after 3 hrs.
Artesian flow g.p.m. Date
Temperature of water [X] Was a chemical analysis made? [] Yes [X] No

(10) CONSTRUCTION:

Well seal—Material used BENTONITE & CUTTINGS
Depth of seal 20 ft.
Diameter of well bore to bottom of seal 12 1/4 in.
Were any loose strata cemented off? [] Yes [X] No Depth
Was a drive shoe used? [] Yes [X] No
Did any strata contain unusable water? [] Yes [X] No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? [] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County MARION Driller's well number
Bearing and distance from section or subdivision corner
1750 FT N. & 350 FT W. OF S.E. COR SEC 2 - T. 7S. R. 1W.

(12) WELL LOG:

Diameter of well below casing 7 1/2

Depth drilled 65 ft. Depth of completed well 65 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

Table with columns: MATERIAL, From, To, SWL. Rows include TOP SOIL & BOULDERS, H. CLAYSTONE GREY, H. CLAYSTONE GREEN, H. SANDSTONE, H. CLAYSTONE GREY.

Work started 9/15 1967 Completed 9/15 1967

Date well drilling machine moved off of well 9/15 1967

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] C.E. Stadelci Date 9/30, 1967
(Drilling Machine Operator)

Drilling Machine Operator's License No. 84

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. STADELI & SONS
(Person, firm or corporation) (Type or print)

Address RT 3 BOX 169, SILVERTON, ORE

[Signed] Paul R. Stadelci
(Water Well Contractor)

Contractor's License No. 296- (9/30 Date 67) 19