

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

RECEIVED

MAY 30 1973

State Well No. 45/1W-18ac

STATE ENGINEER SALEM, OREGON

State Permit No. _____

599
MARION

(1) OWNER:

Name Sylvester Pavlik
Address 3612 S. Front St. Canby Ore.

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Cable Dig Driven Jetted Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
3" Diam. from 7.2 ft. to 164.8" ft. Gage 1250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

PERFORATIONS:

Perforated? Yes No

Type of perforator used Mills knife
Size of perforations in. by in.
240 perforations from 152 ft. to 162' ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " " " "
" " " " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water _____ Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Well seal—Material used Bentonite & Cement
Well sealed from land surface to 35' spudded in ft.
Diameter of well bore to bottom of seal 12" in.
Diameter of well bore below seal 12" in.
Number of sacks of cement used in well seal 1 sacks
Number of sacks of bentonite used in well seal 3 sacks
Brand name of bentonite Boroid
Number of pounds of bentonite per 100 gallons of water 1000 lbs./100 gals.
Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: 3/4-3/8
Gravel placed from 35' ft. to 165' ft.

(10) LOCATION OF WELL:

County Marion Driller's well number _____
N 1/4 SW 1/4 Section 18 T. 4S R. 1W W.M.
Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.

Depth at which water was first found 30 ft.
Static level 35 ft. below land surface. Date 4-21-73
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 0
Depth drilled 165 ft. Depth of completed well 164' ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
top soil	0	2	
beige clay	2	12	
brown silty clay	12	34	
blue clay	34	51	
blue silty clay	51	69	
gray clay	69	82	
bluish silty clay	82	96	
sandy clay	96	100	
small gravel (1")	100	101	
blue silty clay	101	108	
blue silty clay	108	111	
blue sandy clay	111	117	
black sand	117	119	
blue hard clay	119	152	
blue sand gravel (2") (35')	152	165	
we placed concrete 163 1/2 to 165' to plug bottom			

Work started 4-10 1973 Completed 4-21 1973
Date well drilling machine moved off of well 4-21 1973

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Edgar J. Muller Date 5-1, 1973
(Drilling Machine Operator)
Drilling Machine Operator's License No. 581

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Milo Schneider Equipment Co.
(Person, firm or corporation) (Type or print)
Address Star Bldg. Box 97, St. Paul, Ore.
[Signed] Milo Schneider
(Water Well Contractor)
Contractor's License No. 387 Date 5-1-73, 1973