

RECEIVED

MARI 607 45/11W-19 ca

~~APR 23 1987~~

Owner's Well Number:

WATER RESOURCES DEPT. County Marathon

~~WATER RESOURCES DEPT~~

State **OR.**

Zip 97002

~~WATER RESOURCES DEPT~~

County Maruon Latitude " Longitude

County _____
Twp _____
S. Range 1 or W, WM

19 NE $\frac{1}{4}$ SW $\frac{1}{4}$

Section 17 Tax Lot Lot Block Subdivision

Street Address of Well (or nearest address) same

(10) STATIC WATER LEVEL:

32 _____ ft. below land surface.

Date 4-21-87

Artesian pressure _____ lb. per square inch. Date _____

(11) WELL LOG: Ground elevation 100'

Ground elevation 100

[illegible]

Depth of Completed Well 134 ft.

Special Standards date of approval

HOLE		SEAL		Amount sacks or pounds
From	To	Material	From To	
10	0	18 Bentonite	0 18	10 Sacks
6	18	134		

How was seal placed? Method ☐ A ☐ B ☐ C ☐ D ☐ E

☒ Other Granular Bentonite

Backfill placed from _____ ft. to _____ ft. Material _____

Gravel placed from _____ ft. to _____ ft. Size of gravel _____

[illegible]

ion of shoe(s) 130

PERFORATIONS/SCREENS:

[illegible]

(8) WELL TESTS: Minimum testing time is 1 hour

☐ Pump ☐ Bailer ☒ Air ☐ Artesian

Yield gal/min	Pumping level	Drill stem at	Time
---------------	---------------	---------------	------

			1/2 hr
125		120'	1 hr

Temperature of water _____ - Depth Artesian Flow Found _____

Was a water analysis done? ☐ Yes By whom

Did any strata contain water not suitable for intended use? ☐ Too little

☐ Salty ☐ Muddy ☐ Odor ☐ Colored ☐ Other

Depth of strata: _____

(unbonded) Water Well Constructor Certification:

I constructed this well in compliance with Oregon well construction standards. Materials used and information reported above are true to my best knowledge and belief.

Signed _____ Date _____

(bonded) Water Well Constructor Certification:

I accept responsibility for construction of this well and its compliance with all Oregon water well standards. This report is true to the best of my knowledge and belief.

Signed David Danelly Date 4-21-87

Company Donnelly Drilling Co. Co. Job No. _____