

RECEIVED

MAR 6/13
61221

7/1W-6R

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

SEP 28 1958 WATER WELL REPORT
STATE ENGINEER STATE OF OREGON

State Well No. _____
State Permit No. G-967

(1) OWNER: SALEM, OREGON
Name Oliver E. Steff 7077
Address 242 Box 28th
Silverton Oregon

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? Becker Tractor
Yield: 105 gal./min. with 135 ft. drawdown after 5 hrs.

(2) LOCATION OF WELL:
County MARION Owner's number, if any—
SE 1/4 SE 1/4 Section 6 T. 7S. R. 1W. W.M.
Bearing and distance from section or subdivision corner
1800 ft. S. + 863 ft. W. from the 1/4 cor.
common to Sections 5 + 6.

Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 76 Was a chemical analysis made? Yes No

(3) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(12) WELL LOG: Diameter of well 8 inches.
Depth drilled 139 ft. Depth of completed well 139 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

PROPOSED USE (check):
Domestic Industrial Municipal
Irrigation Test Well Other
(5) TYPE OF WELL:
Rotary Driven
Cable Jetted
Dug Bored

MATERIAL	FROM	TO
TOP SOIL	0	8
STICKY YELLOW CLAY	8	20
SANDY CLAY	20	38
SANDY CLAY WITH PEA GRAVEL	38	45
CEMENTED SAND-GRAVEL	45	58
CEMENTED GRAVEL UP TO GOBBLE STONE SIZE	58	80
LOOSE GRAVEL	80	84
CEMENTED GRAVEL	84	104
BLUE SHALE WITH SOME LARGE GRAVEL	104	134
COLORRED COURSE SAND	134	136
GREY LAVA	136	139

(6) CASING INSTALLED:
8" Diam. from 0 ft. to 138 ft. Gage 5 1/2"
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:
Type of perforator used MILLS KNIFE Perforated? Yes No
SIZE of perforations 5/16 in. by 1 1/2 in.
60 perforations from 75 ft. to 100 ft.
30 perforations from 125 ft. to 135 ft.

(8) SCREENS: Well screen installed Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

Work started SEPT 4 1958. Completed SEPT 16 1958

(9) CONSTRUCTION:
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Was a surface seal provided? Yes No To what depth? 40 ft.
Material used in seal— GROUT
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(13) PUMP:
Manufacturer's Name _____
Type: _____ H.P. _____

(10) WATER LEVELS:
Static level _____ ft. below land surface Date _____
Artesian pressure _____ lbs. per square inch Date _____

Well Driller's Statement:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME WILLIAM J. STENNETT
(Person, firm, or corporation) (Type or print)
Address 361 WARNER MILNE RD. OREGON CITY
Driller's well number _____
[Signed] William J. Stennett
(Well Driller)
License No. 5 Date Sept 16, 1958

Log Accepted by: _____
[Signed] Oliver E. Steff Date Sept 16, 1958
(Owner)