

7/1W-9B

Well Water Report

APPL. 61199

PERMIT 61060

Edwin A. Bulliger
 Rt #3 Box 118
 Silverton, Oregon

Excavated Infiltration Trench

Cats were used to excavated the trench.

Log: 0" to 18" Black silt and humus
 18" to 96" grey clay loam
 96" to 120" impervious clay.

Side slopes of trench 1 1/2:1

Ave. Depth 8'

Ave. Length 200'

Ave Width 67'

RECEIVED

DEC 3 1958

STATE ENGINEER
 OREGON

Signed - Edwin A. Bulliger
 Nov 14, 1958