

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

RECEIVED

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT
STATE OF OREGON JUL 29 1975 State Well No. HS/14-19
(Please type or print)
WATER RESOURCES DEPT. State Permit No. _____
(Do not write above this line)
SALEM, OREGON

620
MARI....

(1) OWNER:

Name Donald L. Hulshizer
Address 1132 Ivy Drive
Fairbanks, Alaska 99701

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
6" Diam. from 0 ft. to 158 ft. Gage 250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

PERFORATIONS:

Perforated? Yes No.

Type of perforator used _____

Size of perforations in. by in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " " "
" " " " "
Baller test 40 gal./min. with 10 ft. drawdown after 1 hrs.
Artesian flow g.p.m.

Temperature of water 54 Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Well seal—Material used Bentonite
Well sealed from land surface to 40 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal _____ sacks
Number of sacks of bentonite used in well seal 2 sacks
Brand name of bentonite Yellowstone
Number of pounds of bentonite per 100 gallons
of water 200 lbs./100 gals.
Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County Marion Driller's well number _____
1/4 1/4 Section 19 T4S R. 1W W.M.
Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.

Depth at which water was first found 167 ft.
Static level 40 ft. below land surface. Date 6-28-75
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 6 1/2

Depth drilled 175 ft. Depth of completed well 173 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Soil brown	0	2	
Sandy clay brown	2	16	
Clay grey	16	47	
Sandy clay grey	47	63	
Clay sticky grey	63	75	
Sand grey (dry)	75	98	
Sand black	98	125	
Clay brown	125	130	
Clay grey	130	135	
Sand grey	135	150	
Sand black	150	152	
Clay sticky grey	152	167	
Sand & gravel black W B	167	175	40

Work started 6-23 1975 Completed 6-28 19 75

Date well drilling machine moved off of well 6-28 19 75

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Tom Stites Date 7-7, 19 75
(Drilling Machine Operator)

Drilling Machine Operator's License No. 921

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name A C Stites
(Person, firm or corporation) (Type or print)

Address 28290 S Dryland Rd. Canby, 97013

[Signed] A C Stites
(Water Well Contractor)

Contractor's License No. 533 Date 7-7, 19 75