

STATE OF OREGON
WATER SUPPLY WELL REPORT
 (as required by ORS 637.705)

WELL ID # L 38804
 (START CARD) # 122674

OWNER: Cascade School Dist
 Well Number: Marion Sch
 Name: Cascade School Dist
 Address: 40229 Marion Rd SE
 City: Marion State: OR Zip: 97382

(9) LOCATION OF WELL by legal description:
 County: Marion Latitude: Longitude:
 Township: 9S Nor S. Range: 2W E or W. of 1/4:
 Section: 35 NE 1/4 NE 1/4
 Tax lot: 041001 Lot Block Subdivision:
 Street Address of Well (or nearest address): 6023 B Street, Marion, Oregon

(2) TYPE OF WORK:
 New Well Deepening Alteration (repair/condition) Abandonment

(3) DRILL METHOD:
 Rotary Air Rotary Mud Cable Auger
 Other

(10) STATIC WATER LEVEL:
7 ft. below land surface. Date: 8/11/2000
 Artesian pressure lb. per square inch. Date:

(4) PROPOSED USE:
 Domestic Community Industrial Irrigation
 Commercial Injection Livestock Other School

(11) WATER BEARING ZONES:
 Depth at which water was first found

(5) BORE HOLE CONSTRUCTION:
 Bonded Construction approval Yes No Depth of Completed Well 62 ft.
 Insulated (Yes/No) Yes No Type Amount

From	To	Estimated Flow Rate	SWL
20'	35'	not tested	15'
37.5'	62'	25+ GPM	7'

HOLE SEAL

Diameter	From	To	Material	From	To	Amount
10in	0'	44'	Cement	-1'	44'	20 sacks
6in	44'	62'	Bentonite	0'	-1'	2 sacks

How was seal placed: Method A B C D E
 Other: _____
 Gravel placed from _____ ft. to _____ ft. Material: _____
 Gravel placed from _____ ft. to _____ ft. Size of gravel: _____

(12) WELL LOG:
 Ground elevation

Material	From	To	SWL
Brown sandy clay	0	9	
Brown clay and gravel	9	13	
Gravel: sand with clay	13	20	
Gravel: small to large with brown sand	20	35	
Gravel: light	35	56	
Loose gravel and sand	56	62	

(6) CASING/LINER:

Diameter	From	To	Gauge	Steel	Plastic	Welded	Threaded
Casing: 6in	42'	62'	250	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Liner:				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Final location of shoe(s) 62'

Date started 7/28/2000 Completed 8/10/2000

(7) PERFORATIONS/SCREENS:
 Perforations Method Mill Knife
 Screens Type _____ Material _____

From	To	Slot size	Number	Diameter	Tele/pipe size	Casing	Liner
57.5	60.5	3/16	24			<input checked="" type="checkbox"/>	<input type="checkbox"/>

(unbonded) Water Well Constructor Certification:
 I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards. Materials used and information reported above are true to my best knowledge and belief.

(8) WELL TESTS: Minimum testing time is 1 hour

Pump Bailor Air Flowing Artesian

Yield gal/min	Drawdown	Drift stem at	Time
37 GPM	11.9'		4hrs

Signed _____ WWC Number _____
 Date _____

Temperature of Water 58 Depth Artesian Flow found _____
 Was a water analysis done? Yes No By whom _____
 Did any screens contain water not suitable for intended use? Too little
 Silty Muddy Odor Colored Other _____
 Depth of strata: _____

(bonded) Water Well Constructor Certification:
 I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon water supply well construction standards. This report is true to the best of my knowledge and belief.

Signed Michael Waldrop WWC Number 633
 Date August 31, 2000