

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

RECEIVED AUG 20 1963 STATE ENGINEER SALEM OREGON

WATER WELL REPORT STATE OF OREGON (Please type or print)

MAR 16 26

State Well No. 4/1 w-19

State Permit No.

(1) OWNER:

Name DAVID L. HORNADAY Address RT. I BOX 209 AURORA, OREGON

(2) LOCATION OF WELL:

County MARION Driller's well number 856 1/4 Section I9 T. 4 R. I W.M. Bearing and distance from section or subdivision corner MILLER ACRES LOT 25

(3) TYPE OF WORK (check):

Well [X] Deepening [] Reconditioning [] Abandon [] abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Irrigation [X] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Driven [] Cable [X] Jetted [] Dug [] Bored []

(6) CASING INSTALLED:

Threaded [] Welded [X]

6" Diam. from TOP ft. to I04 ft. Gage 250

(7) PERFORATIONS:

Perforated? [] Yes [X] No

Type of perforator used

Size of perforations in. by in. perforations from ft. to ft. perforations from ft. to ft. perforations from ft. to ft. perforations from ft. to ft. perforations from ft. to ft.

(8) SCREENS:

Well screen installed [] Yes [X] No

Manufacturer's Name Model No. Diam. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal CEMENT & PUTTLE CLAY Depth of seal 18 ft. Was a packer used? Diameter of well bore to bottom of seal 8 in. Were any loose strata cemented off? [] Yes [] No Depth Was a drive shoe used? [X] Yes [] No Was well gravel packed? [] Yes [X] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [] Yes [] No Type of water? Depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 35 ft. below land surface Date Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [X] Yes [] No If yes, by whom? DRILLER

Yield: 200 gal./min. with 60ft. drawdown after 8 hrs.

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? [] Yes [] No

(12) WELL LOG:

Diameter of well below casing

Depth drilled 115 ft. Depth of completed well 115 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows: TOP SOIL (0-20), SAND (20-30), CLAY (30-60), SAND (60-70), CLAY (70-108), SAND (108-115)

Work started AUG. 20 19 63 Completed AUG. 23 19 63

Date well drilling machine moved off of well AUG. 23 19 63

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLAMETTE DRILLING CO. (Person, firm or corporation) (Type or print)

Address RT. 2 BOX 276 SALEM, OREGON.

Drilling Machine Operator's License No. 141

[Signed] Emil O. Beier (Water Well Contractor)

Contractor's License No. 2 Date 8/24/63, 19