

RECEIVED

MAR 10 1963

SEP 23 1963

WATER WELL REPORT

State Well No. 7/w-15

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

STATE ENGINEER SALEM, OREGON

STATE OF OREGON

State Permit No.

(1) OWNER:

Name C.R. PROAPS
Address RT 3, BOX 107-B SILVERTON, OREGON

(2) LOCATION OF WELL:

County MARION Owner's number, if any-
Bearing and distance from section or subdivision corner
700 FT. WEST & 1800 FT. SOUTH OF N.E. COR. OF SEC. 15, T. 7 S., R. 1 W. OF W.M.

(3) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon []
Abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic [X] Industrial [] Municipal []
Irrigation [] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Driven []
Cable [X] Jetted []
Dug [] Bored []

(6) CASING INSTALLED:

6" Diam. from 0 ft. to 28 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? [] Yes [X] No
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed [] Yes [X] No
Manufacturer's Name
Type Model No.
Slot size Set from ft. to ft.
Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Was well gravel packed? [] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.
Was a surface seal provided? [X] Yes [] No To what depth? X ft.
Material used in seal- CEMENT
Did any strata contain unusable water? [] Yes [X] No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 40 ft. below land surface Date 2/21/63
Artesian pressure lbs. per square inch Date
Log Accepted by:
[Signed] Date 19

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? [] Yes [] No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
Bailer test 8 gal./min. with 50 ft. drawdown after 1 hr
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? [] Yes [X] No

(12) WELL LOG:

Diameter of well 6 inches.
Depth drilled 113 ft. Depth of completed well 113 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns: MATERIAL, FROM, TO. Rows include TOP SOIL BROWN, CLAY & BOULDERS BROWN, DECOMPOSED ROCK BRN, HARD BASALT GREY, MED BASALT BRN, HARD BASALT GREY, HARD CLAYSTONE GREY BASALT, WATER COMING FROM.

Work started 2/11 1963 Completed 2/21 1963

(13) PUMP:

Manufacturer's Name UNIVERSAL
Type: SUB H.P. 3/4

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. STADELI & SONS
Address RT 3 BOX 169 SILVERTON
Driller's well number Paul G. Stadel
[Signed] C. E. Stadel
License No. 296 Date 6/30 1964