NOTICE TO WATER WELL CONTRACT

Was well gravel packed?

Yes

No Size of gravel: Gravel placed from _____ft. to _____ft.

The original and first copy of this report are to be

filed with the STATE ENGINEER, SALEM. OREGON 973 within 30 days from the date of well completion.

RECEIVED

WATER WELL REPORT STATE OF OREGON

DEC5 1974 State Well No. 75 IW-18 ba

(Please type or print) STATE ENGINEER tate Permit No. (Do not write above this line SALEM, OREGON

(1) OWNER:	(10) LOCATION OF WELL:
Name Melvin King	County Marion Driller's well number
Address Rt 2 Silverton, Or	N.W. 14 N.W 14 Section 18 T. 7.S. R.1 W. W.M.
	Bearing and distance from section or subdivision corner
(2) TYPE OF WORK (check):	
New Well ☐ Deepening 【 Reconditioning ☐ Abandon ☐	
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 0)rig ft.
Rotary K Driven - Domestic I Industrial Municipal	Static level 60 ft. below land surface. Date 0/25/74
Cable	Artesian pressure lbs. per square inch. Date
CASING INSTALLED: Threaded Welded M. Cig 10" Diam from ft. to ft. Gage	(12) WELL LOG: Diameter of well below casing 10
	Depth drilled 353 ft. Depth of completed well 353 ft.
	Formation: Describe color, texture, grain size and structure of materials;
Diani, Iron Gage	and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in
PERFORATIONS: Perforated? Yes No.	position of Static Water Level and indicate principal water-bearing strata.
Type of perforator used unknown	MATERIAL From To SWL
Size of perforations in. by in.	Orig depth 274
perforations from ft. to ft.	H. Basalt grey seamy& 274 353
perforations fromft. toft.	brn streaks W.B.
perforations from	
(7) SCREENS: Well screen installed? Yes No	
Manufacturer's Name	-
Type Model No	
Diam Slot size Set from ft. to ft.	
Diam. Slot size Set from ft. to ft.	
(8) WELL TESTS: Drawdown is amount water level is	
lowered below static level	
Was a pump test made? E Yes □ No If yes, by whom Stettlers	
eld: 500 gal./min. with 100 ft. drawdown after hrx	
375 " 71 " 3 "	
" 350 " 64° " \Q"	
Refer test 600 gal./min. with 290 ft. drawdown after 1hrs.	
Artesian flow g.p.m.	
artesian flow g.p.m. apperature of water Depth artesian flow encountered	Work started 10/21/74 19 Completed 10/25/74 19
Depart accessariation encountered	
(9) CONSTRUCTION:	Date well drilling machine moved off of well 10/25/74 19
Well seal—Material used	Drilling Machine Operator's Certification:
Well sealed from land surface toft.	This well was constructed under my direct supervision. Materials used and information reported above are true to my
Diameter of well bore to bottom of seal in.	best knowledge and belief.
Diameter of well bore below sealin.	[Signed] Steve Stade L: Date 11/6/74 19
Number of sacks of cement used in well seal sacks	(Drilling Machine Operator)
Number of sacks of bentonite used in well seal sacks	Drilling Machine Operator's License No860
Brand name of bentonite	Water Well Contractor's Contification
Number of pounds of bentonite per 100 gallons	Water Well Contractor's Certification:
of water lbs./100 gals.	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Was a drive shoe used? Yes No Plugs Size: location ft.	Name R. Stadelie SonsTre
Did any strata contain unusable water? 🛛 Yes 📋 No	Name R. Stadeli& SonsInc. (Person, firm or corporation) (Type or print)
Type of water? depth of strata	Address Silverton, Oreg
Method of sealing strata off	() 0 () St 1.1.
Was well gravel packed? ☐ Yes ☐ No Size of gravel:	[Signed] Jaw J. Madda (Water Well Contractor)
Gravel placed from ## to ##	Contractor's License No 296 Date 11/6/74