NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT. SALEM, OREGON 97310 within 30 days from the date

Gravel placed from ft. to

Cable

Dug

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

State Well No.

State Permit No.6-8 of well completion. (Do not write above this line) nust new / So (10) LOCATION OF WELL: (1) OWNER: Donald Mantie Driller's well number Name 9700 Sunnyview Drive NE SE NW 14 SE 14 Section 19 T. 7S R. 1W Address W.M. Salem, Oregen 97301 Bearing and distance from section or subdivision corner (2) TYPE OF WORK (check): Deepening [Reconditioning [Abandon [New Well X If abandonment, describe material and procedure in Item 12. (11) WATER LEVEL: Completed well. (3) TYPE OF WELL: (4) PROPOSED USE (check): Depth at which water was first found Driven 🗆 Rotary Domestic | Industrial | Municipal | ft. below land surface. Date Static level $\overline{\Box}$ Jetted П Bored Irrigation X Test Well [Other Artesian pressure lbs. per square inch. Date CASING INSTALLED: Threaded [] Welded M (12) WELL LOG: Diameter of well below casing .. 365 Depth drilled ft. Depth of completed well " Diam. from ft. to ft. Gage Formation: Describe color, texture, grain size and structure of materials; ..." Diam, from ft. to ft. Gage and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata, PERFORATIONS: Perforated? Tyes X No. MATERIAL Type of perforator used Top Seil Brown Size of perforations in. by 4 Clay Brown perforations from _____ ft. to _____ ft. Clay Yellow perforations from _____ ft. to _____ ft. Rock Medium Brown _____ perforations from _____ ft. to _____ ft. Clay Yellow 46 (7) SCREENS: Well screen installed? | Yes | No Basalt Medium Brown 73 78 Manufacturer's Name Basalt Hard Grev 78 132 132 Basalt & Cool Medium Black 135 W.B. Diam. Slot size Set from ft. to ft. Weathered Basalt Med. Brown 135 W.B. Diam. Slot size Set from ft. to ft. 744 Basalt Hard Grey 152 Veathered Basalt Med. 152 Drawdown is amount water level is lowered below static level (8) WELL TESTS: 178 247 Basalt Hard Grey Was a pump test made? ☐ Yes ■ No If yes, by whom? Basalt Medium Poreum Black 247 W.B. Basalt Hard Grev 258 292 gal./min. with ft. drawdown after Yield: hrs. Weathered Basalt Med. & Seamy Basalt Hard Grev Barr test appr. 250al./min. with 288 ft. drawdown after hrs. Sandstone Hard Artesian flow g.p.m. perature of water Depth artesian flow encountered Work started 10/2 1978 Completed 10/3 19 78 10/4 Date well drilling machine moved off of well (9) CONSTRUCTION: Well seal-Material used Bentonite (National Brand) Drilling Machine Operator's Certification: Well sealed from land surface to 20 Diameter of well bore to bottom of seal 2"

Diameter of well bore below seal in. Webate 10/5 , 1978 Number of sacks of cement used in well seal Drilling Machine Operator's License No. How was cement grout placed? One sack of bentonite used. Gravity placed. Water Well Contractor's Certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Was a drive shoe used? 🗌 Yes 苍 No Plugs Size: location Name West Coast Drilling Co., Inc.
(Person, firm or corporation) (Type or print) Did any strata contain unusable water? 🗌 Yes 🕱 No Address 220 Academy St., Mt. Angel, OR 97362 Type of water? depth of strata Method of sealing strata off Was well gravel packed? [] Yes 🔀 No Size of gravel:

Contractor's License No. 519 Date 10/5 1978