

**STATE OF OREGON
WATER SUPPLY WELL REPORT**

(ORS 537.765 & OAR 690-205-0210)

Instructions for completing this report are on the last page of this form.

MARI 64116

WELL LABEL # L _____

START CARD # 1015730

ORIGINAL LOG # MARI 5729-5732

(1) LANDOWNER Owner Well I.D. 5234
 First Name _____ Last Name _____
 Company City of Scotts Mills
 Address P.O. Box 220
 City Scotts Mills State OR Zip 97374

(2) TYPE OF WORK New Conversion Deepening
 Alteration (complete Sections 2a & 10) Abandonment (complete Section 5a)

(2a) PRE-ALTERATION: Well Depth _____ ft.
 Seal Material _____
 Casing Type: Steel Plastic Other _____
 Casing Gauge _____ Casing Diameter _____

(3) DRILL METHOD Rotary Air Rotary Mud Auger
 Cable Cable Mud Reverse Rotary Other _____

(4) PROPOSED USE Domestic Irrigation Community
 Industrial/Commercial Livestock Dewatering Injection
 Thermal Other _____

(5) BORE HOLE CONSTRUCTION
 Depth of Completed Well 0 ft. Special Standard: Yes (attach copy)

BORE HOLE				SEAL			
Dia	From	To	Material	From	To	Amount	Scks/lbs
8	0	110	Cement	0	110	30	sacks
8	110	340	Bentonite	110	340	102	Sacks

How was seal placed: Method A B C D E
 Other _____
 Backfill placed from _____ ft. to _____ ft. Material _____
 Filter pack from _____ ft. to _____ ft. Material _____ Size _____

(5a) ABANDONMENT USING UNHYDRATED BENTONITE:
 Calculated Amount Proposed to be Used: 130 sacks _____ sacks/lbs
 Actual Amount Used: 102 sacks _____ sacks/lbs
Poured dry & probed every 10 sacks

(6) CASING/LINER

Csng	Linr	Dia	+	From	To	Gauge	Steel	Plastic	Welded	Thrd

Shoe Inside Outside Other Location of shoe(s) _____
 Temporary casing Yes Diameter _____ From _____ To _____

(7) PERFORATIONS/SCREENS
 Perforations Method Air perforator
 Screens Type _____ Material _____

Perf	Scrn	Csng	Linr	Screen Dia	From	To	Screen/ slot width	Slot length	# of slots	Tele/ pipe size
✓	✓				50	92	3/8	1	1600	
✓	✓				20	40	3/8	1	1600	

(8) WELL TESTS: Minimum testing time is 1 hour
 Pump Bailor Air Flowing Artesian
 Yield gal/min _____ Drawdown _____ Drill stem/Pump depth _____ Duration (hr) _____
 Temperature _____ °F Lab analysis Yes By _____
 Water quality concerns? Yes (describe below) TDS 197 ppm

From	To	Description	Amount	Units

(9) LOCATION OF WELL (legal description)
 County Marion Twp 6 N or S Range 1 E or W W.M.
 Sec 22 NW 1/4 of the NE 1/4 Tax Lot 2300
 Tax Map Number _____ Lot _____
 Lat _____ ° _____ ' _____ " or _____ DMS or DD
 Long _____ ° _____ ' _____ " or _____ DMS or DD
 Street Address of Well (or nearest address) W. end of 6th St.
Scotts Mills, OR

(10) STATIC WATER LEVEL

	Date	SWL (psi)	+	SWL (ft)
Existing Well/Pre-Alteration				
Completed Well				

Flowing Artesian? Yes Dry Hole? Yes

WATER BEARING ZONES Depth water was first found _____

SWL Date	From	To	Est Flow	SWL (psi)	+	SWL (ft)

(11) WELL LOG Ground Elevation _____

Material	From	To
pulled pump. Bailed hole to 340'		
Verified original perforations at 38'-50'		
Perforate casing from 50' to 92' and 20' to 40'		
Poured dry bentonite from 340' up to 110', probing every 10 sacks. Pumped cement from 110' to surface and pressurize cement. Cut casing below grade topped cement off to surface!		
		RECEIVED
		FEB 13 2012
		WATER RESOURCES DEPT
		SALEM, OREGON

Date Started 2-06-12 Completed 2-07-2012

(unbonded) Water Well Constructor Certification
 I certify that the work I performed on the construction, deepening, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards. Materials used and information reported above are true to the best of my knowledge and belief.

License Number 1411 Date 2-08-2012

Signed KTD Mats

(bonded) Water Well Constructor Certification
 I accept responsibility for the construction, deepening, alteration, or abandonment work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon water supply well construction standards. This report is true to the best of my knowledge and belief.

License Number 1684 Date 2-08-2012

Signed Jones
 Contact Info. (optional) Jones Drilling Co., Inc.
29400 Santiam Hwy.
Lebanon, OR 97355
541-367-2560
jonesdrilling@hotmail.com