

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED

DEC 7 1966

6439
MAR 1966

WATER WELL REPORT

STATE ENGINEER OF OREGON SALEM, OREGON (Please type or print)

G-3790

State Well No. 7/1w-34 M
State Permit No.

(1) OWNER:

Mrs. Ida Johnson
Name
1395 Cascade Hiway, Salem, Oreg
Address
S.E.

(2) LOCATION OF WELL:

County Marion Driller's well number
1/4 1/4 Section T. R. W.M.
Bearing and distance from section or subdivision corner
1800ft N. & 1300ft E. of S.W. cor
Sec 34 T7S R.1W.

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other
(5) TYPE OF WELL:
Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

6" Threaded Welded
0 62 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed? Yes No

Manufacturer's Name Model No.
Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite & cuttings
Depth of seal 55 ft. Was a packer used? no
Diameter of well bore to bottom of seal 12 1/4 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 23 ft. below land surface Date 11/10/66
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " " "
Air " " " " "
Pump test 27 gal./min. with 68 ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date
Temperature of water xx Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 6"

Depth drilled 96 ft. Depth of completed well 96 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top soil brn	0	2
Clay & boulders red	2	60
H. Basalt grey	60	64
M. Basalt pounce w.b. grey	64	88 92
Soft claystone grey	92	96

Work started 11/7 1966 Completed 11/10 66
Date well drilling machine moved off of well 11/10 66

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. Stadel & Sons
(Person, firm or corporation) (Type or print)
Address Rt 3 Box 169, Silverton, Oreg

Drilling Machine Operator's License No. 322-84

Signed Paul R. Stadel
(Water Well Contractor)

Contractor's License No. 296 Date 12/5 66