

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER WELL REPORT

6468
MARION.....

WATER RESOURCES DEPARTMENT.
SALEM, OREGON 97310
within 30 days from the date
of well completion.

STATE OF OREGON
(Please type or print)

State Well No. 7s/zw-1bd
State Permit No. G8951

(Do not write above this line)

(1) OWNER:

Name Wayne Steffen
Address 10143 Silverton Rd. NE
Silverton, Oregon 97381

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
 Jetted
 Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
10" Diam. from +1 ft. to 199 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? Yes No.

Type of perforator used Hawk Air Perforator
Size of perforations 3/8 in. by 3/4 in.
2520 perforations from 120 ft. to 180 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is
lowered below static level

a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " " "
" " " " "
AIR
Flow test 500 gal./min. with 161 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Cement Grout
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 14 in.
Diameter of well bore below seal 10 in.
Number of sacks of cement used in well seal 34 sacks
How was cement grout placed? Pressure

Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Marion Dfiler's well number
SE 1/4 NW 1/4 Section 1 T. 7S R. 2W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 76 ft.
Static level 39 ft. below land surface. Date 3/17/80
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 10"

Depth drilled 200 ft. Depth of completed well 200 ft.

Formation: Describe color, texture, grain size and structure of materials;
and show thickness and nature of each stratum and aquifer penetrated,
with at least one entry for each change of formation. Report each change in
position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Soil	0	1	
Clay Brown	1	26	
Clay Grey Sticky	26	37	
Claystone Brown Med.	37	46	
Claystone Grey Med.	46	76	
Conglomerate Large	76	170	WB
Clay Brown w/ sm. gravel	170	176	
Sand Brown Course	176	185	WB
Sand Grey Course & Med.	185	199	WB
Clay Brown	199	200	

RECEIVED

APR 2 1980

WATER RESOURCES DEPT
SALEM, OREGON

Work started 3/10 19 80 Completed 3/17 19 80
Date well drilling machine moved off of well 3/17 19 80

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision.
Materials used and information reported above are true to my
best knowledge and belief.

[Signed] Byron Stebb Date 3/27, 1980
(Drilling Machine Operator)

Drilling Machine Operator's License No. 1371

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is
true to the best of my knowledge and belief.

Name West Coast Drilling Co., Inc.
(Person, firm or corporation) (Type or print)

Address 220 Academy St., Mt. Angel, OR 9736

[Signed] Charles C. Stebb
(Water Well Contractor)

Contractor's License No. 519 Date 3/27, 1980