

RECEIVED

MAR 13 1965

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER STATE OF OREGON

SALEM OREGON within 30 days from the date of well completion.

SALEM OREGON (Please type or print)

State Well No. 7/2w-1M

State Permit No. G3333

(1) OWNER:

Name Cecil Roth
Address Rt. 2 Box 268
Silverton Ore.

(2) LOCATION OF WELL:

County Marion Driller's well number
1/4 NE 1/4 Section 1 T. 7 S R. 2 W W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ]
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [ ] Industrial [ ] Municipal [ ]
Irrigation [X] Test Well [ ] Other [ ]

(5) TYPE OF WELL:

Rotary [X] Driven [ ]
Cable [ ] Jetted [ ]
Dug [ ] Bored [ ]

(6) CASING INSTALLED:

Threaded [ ] Welded [X]
12" Diam. from 0 ft. to 160 ft. Gage 7

(7) PERFORATIONS:

Perforated? [X] Yes [ ] No
Type of perforator used MILLS
Size of perforations 5/16 in. by 3" in.
1176 perforations from 7.0' ft. to 155' ft.

(8) SCREENS:

Well screen installed? [ ] Yes [X] No
Manufacturer's Name
Model No.
Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal BENTONITE
Depth of seal 40 ft. Was a packer used? YES
Diameter of well bore to bottom of seal 15" in.
Were any loose strata cemented off? [ ] Yes [X] No
Was a drive shoe used? [X] Yes [ ] No
Was well gravel packed? [ ] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? [X] Yes [ ] No
Type of water? SANDY Depth of strata 30' to 61'
Method of sealing strata off CASED

(10) WATER LEVELS:

Static level 25' 6" ft. below land surface Date 9-8-65
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? [X] Yes [ ] No If yes, by whom? SUPPLY
Yield: 600 gal./min. with 36 ft. drawdown after 7 hrs.
Baller test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 53.4 Was a chemical analysis made? [ ] Yes [X] No

(12) WELL LOG:

Diameter of well below casing 12"
Depth drilled 160' ft. Depth of completed well 160' ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include TOPSOIL, CLAY YELLOW COLOR, CLAY BLUE COLOR, SAND BLACK FINE GRAIN, GRAVEL - MUDDY, CONGLOMERATE WATER B., CLAY YELLOW COLOR, CONGLOMERATE WATER B., CLAYSTONE GRAY-SOFT.

Work started 8-28 1965 Completed 9-8 1965
Date well drilling machine moved off of well 9-8 1965

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J. A. SHEED - SONS (Person, firm or corporation) (Type or print)
Address 3910 SILVERTON RD. SALEM ORE.

Drilling Machine Operator's License No. 187

[Signed] J. A. Sheed (Water Well Contractor)

Contractor's License No. 6 Date 9-8-65