

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED
MAY 24 1968

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

State Well No. 7/2w-2

State Permit No. _____

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date

of well completion. SALEM, OREGON

(1) OWNER:

Name GERALD E. Roth
Address Rt. 2 - Box 539

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
10" Diam. from 1 ft. to 171 ft. Gage .250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

PERFORATIONS:

Perforated? Yes No.

Type of perforator used Miller
Size of perforations 1/2 in. by 2 in.
72 perforations from 72 ft. to 76 ft.
248 perforations from 90 ft. to 105 ft.
296 perforations from 115 ft. to 133 ft.
120 perforations from 154 ft. to 161 ft.
perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WATER LEVEL: Completed well.

Static level 35 ft. below land surface Date 5-23-68
Artesian pressure _____ lbs. per square inch Date _____

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level.

Was a pump test made? Yes No If yes, by whom? Robinson & West
Yield: 400 gal./min. with 28 ft. drawdown after 1/2 hrs.
550 " 39 " 1 "
" 590 " 69 " 3 "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used BENTONITE & DRILL CUTTINGS
Depth of seal 30 ft.
Diameter of well bore to bottom of seal 15 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(11) LOCATION OF WELL:

County WAGON Driller's well number _____
1/4 1/4 Section 2 T. 2 S. R. 2 W. W.M.
Bearing and distance from section or subdivision corner _____

(12) WELL LOG:

Diameter of well below casing 10

Depth drilled 170 ft. Depth of completed well 170 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
BROWN - SOIL	0	2	
" - CLAY	2	19	
BLUE - "	19	48	
BROWN - "	48	54	
" - PACKED SAND	54	63	
" - CLAY	63	70	
MED. + SMALL GRAVEL	70	76	
BROWN - CLAY	76	82	
" - CEMENTED GRAVEL	82	89	
SMALL TO LARGE GRAVEL	89	96	
BROWN - CEMENTED "	96	115	
MED. GRAVEL	115	120	
BROWN - CEMENTED GRAVEL	120	123	
SMALL + MED GRAVEL	123	133	
BROWN SAND + MED. "	133	140	
" - CEMENTED GRAVEL	140	154	
SMALL + MED. "	154	161	
BROWN - CEMENTED "	161	170	

Work started 5-13 - 1968 Completed 5-23 1968

Date well drilling machine moved off of well 5-23 - 1968

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Wm. T. Fennell Date 5-23, 1968
(Drilling Machine Operator)

Drilling Machine Operator's License No. 455

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Miller - Robinson & West
(Person, firm or corporation) (Type or print)

Address 5545 Joseph St - S.E. Salem

[Signed] Walter A. Miller
(Water Well Contractor)

Contractor's License No. 37 Date 5-23, 1968