

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy  
of this report are to be  
filed with the

**RECEIVED**  
APR 4 1969

**WATER WELL REPORT**

MA 116493  
11.1.73

STATE ENGINEER, SALEM, OREGON 97310 (Please type or print)  
within 30 days from the date of well completion. SALEM OREGON (Do not write above this line)

State Well No. 7/2W-2 ac

State Permit No. G-4838

**(1) OWNER:**

Name Don Kuenzi  
Address 8153, Silverton, Rd, Silverton Salem

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon

If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**

Rotary  Driven   
Cable  Jetted   
Dug  Bored

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

**CASING INSTALLED:**

Threaded  Welded   
10" Diam. from 0 ft. to 186 ft. Gage 250  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

**PERFORATIONS:**

Perforated?  Yes  No.

Type of perforator used Mills  
Size of perforations 3/8 in. by 3 in.  
705 perforations from 105 ft. to 152 ft.  
60 perforations from 163 ft. to 167 ft.  
105 perforations from 175 ft. to 182 ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

**(7) SCREENS:**

Well screen installed?  Yes  No

Manufacturer's Name  
Type Model No.  
Diam. Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

**(8) WATER LEVEL: Completed well.**

Static level 39 ft. below land surface Date 3-25-69  
Artesian pressure lbs. per square inch Date

**(9) WELL TESTS:**

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom? Driller  
Yield: 550 gal./min. with 76 ft. drawdown after 1 hrs.  
" " " "  
" " " "  
Bailer test gal./min. with ft. drawdown after hrs.  
Artesian flow g.p.m. Date  
Temperature of water Was a chemical analysis made?  Yes  No

**(10) CONSTRUCTION:**

Well seal—Material used Bentonite  
Depth of seal 18 ft.  
Diameter of well bore to bottom of seal 14 in.  
Were any loose strata cemented off?  Yes  No Depth  
Was a drive shoe used?  Yes  No  
Did any strata contain unusable water?  Yes  No  
Type of water? depth of strata  
Method of sealing strata off  
Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.

**(11) LOCATION OF WELL:**

County Marion Driller's well number  
1/4 1/4 Section T. R. W.M.

Bearing and distance from section or subdivision corner  
2000 ft S. 1700 ft W. of N.E. cor of sec 2, T.7S, R.2W.

**(12) WELL LOG:**

Diameter of well below casing 0

Depth drilled 185 ft. Depth of completed well 185 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Top soil brn.	0	2	
Clay brn.	2	28	
Clay grey.	28	48	
Clay brn.	48	71	
Sand brn med.	71	74	
Sandy clay brn.	74	88	
Conglom brn med dirty.	88	105	
Conglom grey med. w.b.	105	154	
Sandy clay brn.	154	160	
Conglom brn med. w.b.	160	169	
Sand brn med packed.	169	170	
Conglom grey med. w.b.	170	183	
Sandy clay grey.	183	185	

Work started 3-10-69 19 Completed 3-25-69 19  
Date well drilling machine moved off of well 3-25-69 19

**Drilling Machine Operator's Certification:**

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Paul R. Stadel Date 4-3-69, 19...  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 322

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. Stadel & Sons  
(Person, firm or corporation) (Type or print)

Address Route 8, Box 169, Silverton, Ore

[Signed] Paul R. Stadel  
(Water Well Contractor)

Contractor's License No. 296 Date 4-3-69, 19...