

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON, within 30 days from the date of well completion

WATER WELL REPORT

STATE OF OREGON

(Please type or print)
(Do not write above this line)

State Well No. 7/2W-2cca

State Permit No. _____

RECEIVED
DEC 8 1968

6-6437 G-4683

(1) OWNER:

Name Elmer Haury
Address _____

STATE ENGINEER
SALEM, OREGON

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Cable Dug
Driven Jetted Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
8" Diam. from 0 ft. to 180 ft. Gage 250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

PERFORATIONS:

Perforated? Yes No.

Type of perforator used Mills
Size of perforations $\frac{1}{4}$ in. by $2\frac{1}{2}$ in.
1044 perforations from 80 ft. to 167 ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____ Model No. _____
Type _____ Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WATER LEVEL: Completed well.

Static level 31 ft. below land surface Date II-20-68
Artesian pressure _____ lbs. per square inch Date _____

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? Driller
Pump: 200 gal./min. with 31 ft. drawdown after $2\frac{1}{2}$ hrs.
300 " " 49 " " $2\frac{1}{2}$ "
475 " " 93 " " $1\frac{1}{2}$ "
Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used Bentonite
Depth of seal 20 ft.
Diameter of well bore to bottom of seal 13 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(11) LOCATION OF WELL:

County Marion Driller's well number _____
 $\frac{1}{4}$ Section T. R. W.M.

Bearing and distance from section or subdivision corner
I300 ft N, I200 ft E. of S.W. cor of sec 2, T.7S, R.2W.

(12) WELL LOG:

Diameter of well below casing _____
Depth drilled I80 ft. Depth of completed well I70 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Top soil brn.	0	I	
Clay brn.	I	II	
Clay sandy brn.	II	I8	
Clay sandy grey,	I8	55	
Clay sandy brn.	55	68	
Conglom brn, med.w.b.	68	I43	
Loose gravel & sand			
brn, med w.b.	I43	I6I	
Conglom brn med w.b.	I6I	I67	
Clay grey.	I67	I80	

Work started I0-27-68 19 Completed II-20-68 19
Date well drilling machine moved off of well II-20-68 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Paul R. Stadel Date 11-21, 1968
(Drilling Machine Operator)

Drilling Machine Operator's License No. 322

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. Stadel & Sons
(Person, firm or corporation) (Type or print)

Address Route 3, Box 169, Silverton, Ore

[Signed] Paul R. Stadel
(Water Well Contractor)

Contractor's License No. 296 Date 12-1, 1968