ORIGINAL
File Original, and Duplicate with the STATE ENGINEER, SALEM, OREGON

6515
M 19[illegible]

WATER WELL DRILLERS REPORT
STATE OF OREGON

Do Not Fill In — State Well No. 7/2W-3G(1)
State Permit No. G 33 App. G126

(1) OWNER:
Name Jensen Bros.
Address Box 323, Rte. 6
Salem, Oregon

(2) LOCATION OF WELL:
County Marion — Owner's number, if any—
R. F. D. or Street No. Rte. 6, Box 323, Salem, Oregon
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
New well [X] — Deepening [] — Reconditioning [] — Abandon []
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):
Domestic [X] — Industrial [] — Municipal []
Irrigation [] — Test Well [] — Other []

(5) EQUIPMENT:
Rotary []
Cable [X]
Dug Well []

(6) CASING INSTALLED:
Threaded [] — Welded [X]

FROM	ft. to	ft.	Diam.	Gage or Wall
"	0	154	12"	5/16
"	"	"	"	"
"	"	"	"	"
"	"	"	"	"
"	"	"	"	"

Type and size of shoe or well ring
Describe joint 5/8 x10 x12Welded Steel Driveshoe

If gravel packed

Diameter of Bore	from ft.	to ft.
	"	"
	"	"
	"	"
	"	"
	"	"

Size of gravel:

(7) PERFORATIONS:
Type of perforator used Mills 12" Perferator
SIZE of perforations 3 in., length by 3/8 in.

FROM	ft. to	ft.	perf per foot	No. of rows
"	XXXX	XXXX	XXXXXXXXXXXXXXXX	XXXX
"	"	"	" " "	" "
100	" 151	"	1 every" 18"	" "8"
"	"	"	" " "	" " "

SCREENS:
Give Manufacturer's Name, Model No. and Size
none

(8) CONSTRUCTION:
Was a surface sanitary seal provided? [X] Yes [] No To what depth ft.
Were any strata sealed against pollution? [X] Yes [] No
If yes, note depth of strata

FROM	ft. to	ft.
"	0"	40

METHOD OF SEALING Sand & Clay

(9) WATER LEVELS:
Depth at which water was first found 17 ft.
Standing level before perforating 37 ft.
Standing level after perforating 30 ft.

Log Accepted by:
[Signed] Dated, 19.....
Owner

(10) WELL TESTS:
STADELI PUMP SERVICE
Was a pump test made? [X] Yes [] No If yes, by whom?

Yield:	gal./min. with	ft. draw down after	hrs.
100	X	52 ft.	8 "
300	"	92 ft.	8 "

Artesian flow g.p.m.
Shut-in pressure lbs. per square inch.
Bailer test g.p.m. with ft. drawdown
Temperature of water X Was a chemical analysis made? [] Yes [X] No
Was electric log made of well? [] Yes [X] No

(11) WELL LOG:
Diameter of well, 12 inches.
Total depth 154 ft. Depth of completed well 154 ft.
Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

ft. to	ft.
0'	4"-Top Soil
4'	15'-Loam -brown
15	40'- Sand-caving-brown(water)
40'	50' -Sand-solider formation-br
50'	58 "- Clay-blue
58'	66 "-Clay-brown
66'	93 "-Cement gravel-grey(water)
93	100 "-Sand &Gravel-grey(water)
100	117 "-Cement grael-grey(water)
117	119 "-Sand &Gravel-grey(water)
119	128 "-Cement gravel-grey(water)
128	130 "-Sand &Gravel-grey (water)
130	141 "-Cement gravel-grey(water)
141	143 "-Sand & Gravel-grey(water)
143	154 "-Cement gravel-grey(water)
"	"
"	"
"	"
"	"
"	"
"	"
"	"
"	"
"	"
"	"
"	"
"	"

Ground elevation at well site 200 feet above mean sea level.
Work started Sept. 19 1955. Completed Oct. 14 1955

Well Driller's Statement:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. Stadeli &Sons.
(Person, firm, or corporation) (Typed or printed)
Address Rte. 3, Box 177A, Silverton, Ore.
Driller's well number
[Signed] R. Stadeli
(Well Driller)
License No. 84 Dated Sept. 16, 1955