

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

6568
121

WATER WELL REPORT

STATE OF OREGON STATE ENGINEER
(Please type or print) SALEM, OREGON
(Do not write above this line)

RECEIVED
JUN 19 1967

State Well No. *7/2w-4P*
State Permit No. _____

G-4032

(1) OWNER:

Name *ROY W. FISKE*
Address *5933 SILVERTON RD. N.E. SALEM ORE*

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
6" Diam. from *0* ft. to *91* ft. Gage *17.02*
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

PERFORATIONS:

Perforated? Yes No.

Type of perforator used _____
Size of perforations in. by in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WATER LEVEL: Completed well.

Static level *24'3"* ft. below land surface Date *6-12-67*
Artesian pressure _____ lbs. per square inch Date _____

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? _____
Yield: gal./min. with _____ ft. drawdown after _____ hrs.
" " " " " "
" " " " " "
Bailer test *50* gal./min. with *50* ft. drawdown after *1* hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water *52* Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used *BENTONITE*
Depth of seal *40* ft.
Diameter of well bore to bottom of seal *9 1/2* in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? *SANDY* depth of strata *84' to 89'*
Method of sealing strata off *CASED*
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(11) LOCATION OF WELL:

County *MARION* Driller's well number _____
1/4 1/4 Section *4* T. *7S* R. *2W* W.M.
Bearing and distance from section or subdivision corner _____

(12) WELL LOG:

Diameter of well below casing *6"*

Depth drilled *91* ft. Depth of completed well *91* ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
TOPSOIL	0	3	
CLAY YELLOW COLOR	3	42	
CLAY BLUE SANDY	42	72	
CONGLOMERATE	72	84	
SAND-BROWN-FINE TO MED.	84	89	24'3"
GRAVEL 1 1/2"	89	91	24'3"

Work started *6-10-1967* Completed *6-12-1967*
Date well drilling machine moved off of well *6-12-1967*

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] *B.J. Sneed* Date *6-12-1967*
(Drilling Machine Operator)

Drilling Machine Operator's License No. *187*

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME *J.A. SNEED & SONS*
(Person, firm or corporation) (Type or print)

Address *3910 SILVERTON RD SALEM ORE.*

[Signed] *B.J. Sneed*
(Water Well Contractor)

Contractor's License No. *6* Date *6-12-67*