STATE ENGINEER Salem, Oregon



STATE WELL NO. 7/2W-5L(1)
COUNTY Marion
APPLICATION NO. GR-329

| OWNER: John Jeffery | MAILING ADDRESS: | 5220 Haveville Drive |
|--|-----------------------------------|----------------------|
| LOCATION OF WELL: Owner's No. #1 | | |
| | | Salem, Oregon |
| NE 14 SW 14 Sec. 5 T. 7 S., R. 2 V | z. V., W.M. | |
| Bearing and distance from section or subdivision | | |
| corner 2800 feet East and 3200 feet South | of NW | |
| corner, Section 5 | ································· | |
| | | 4 [3] |
| | | |
| Altitude at well 182 feet interpolated | | |
| TYPE OF WELL: Drilled Date Constructed | uly, 1950 | |
| Depth drilled 73 feet Depth cased 70 | feet | Section5 |
| CASING RECORD: | | |
| 8-inch casing set from 0 to 70 feet | | |
| | | |
| | | |
| FINISH: | | |
| perforated from 50 to 70 feet | | |
| | | |
| AQUIFERS: | | |
| unk | | |
| WATER LEVEL: | | |
| 50 feet below land surface | | |
| PUMPING EQUIPMENT: TypeBerkeley Capacity559 | | H.P15 |
| WELL TESTS: | | |
| Drawdown25 ft. after | hourspu | mping 550 G.P.M. |
| Drawdown ft. after | hours | G.P.M. |
| USE OF WATER Irrigation 49 | Temp | °F, 19 |
| SOURCE OF INFORMATIONGR-311 | | |
| ADDITIONAL DATA: | | |
| Log <u>no</u> Water Level Measurements | Chemical Aı | nalysis Aquifer Test |
| REMARKS: | | |