NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER RESOURCES DEPARTMENT SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT CEIV State Well No.

(Please type or print)

(Do not write above this line) MAY 26 1978 State Permit No. .

(1) OWNER:	(10) LOCATION, OF EWELL:
Name Don Brockman	
Address _C /o P.O. Box 605	- AT 70 - OT
Woodhurn, Oregon 97071	Bearing and distance from section or subdivision corner
(2) TYPE OF WORK (check):	Subdivision comer
New Well ☑ Deepening □ Reconditioning □ Abandon □	
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 66 ft.
Rotary 🛱 Driven 🛘 Domestic 💢 Industrial 🗀 Municipal 🗀	Static level 51 ft. below land surface. Date 5/5/78
Dug	Artesian pressure lbs. per square inch. Date
CASING INSTALLED: Threaded □ Welded ⋈ 6 "Diam. from top ft. to 100 ft. Gage	(12) WELL LOG: Diameter of well below casing Depth drilled 100 ft. Depth of completed well 100 ft. Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aguifer penetrated.
PERFORATIONS: Perforated? Yes No.	with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.
Type of perforator used	MATERIAL From To SWL,
Size of perforations in. by in.	Topsoil o 2
perforations from	Brown Clay 2 56
perforations from	Brown Sandy Clay 56 66
	Brown Sand and Gravel 66 85 Cemented Black Sand and Gavel 85 94
(7) SCREENS: Well screen installed? ☐ Yes 💢 No	Brown Sand and Gravel 94 100
Manufacturer's Name	
Type	
Diam. Slot size Set from ft. to ft.	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	
Was a pump test made? ☐ Yes Ø No If yes, by whom?	
Yield: gal./min. with ft. drawdown after hrs.	
rtest 60 GPM for a period of 1 hour "	
" " " " "	
Bailer test gal./min. with ft. drawdown after hrs.	
Artesian flow g.p.m.	
perature of water Depth artesian flow encountered	West state 1
To a second seco	Work started $5/5/78$ 19 Completed $5/5/78$ 19 Date well drilling machine moved off of well $5/5/68$ 19
(9) CONSTRUCTION:	Date well drilling machine moved off of well 3/3/68 19
Well seal—Material used Portland Cement Well sealed from land surface to 35 ft. Diameter of well bore to bottom of seal 10 in. Diameter of well bore below seal 6 in. Number of sacks of cement used in well seal 11 sacks How was cement grout placed? annular space bailed dry	Drilling Machine Operator's Certification: This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief. [Signed] Oprilling Machine Operator) Drilling Machine Operator's License No
then grout poured in from the top	
	Water Well Contractor's Certification:
Was a drive shoe used?	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Did any strata contain unusable water? 🗌 Yes 🗶 No	Name Willamette Drilling Co. (Person, firm or corporation) (Type or print) 302
Type of water? depth of strata	Address 1450 Barnick Rd. NE Salem, Oregon 97072x
Method of sealing strata off	[Signed] Dallos & Bris
Was well gravel packed? [] Yes [XNo Size of gravel:	(Water Well Contractor)
Gravel placed from ft. to ft.	Contractor's License No. <u>561</u> Date <u>5/6/78</u> , 19