7/2W-6A

State Permit No. ..

The original and first cory
of this report are to
filed with the
WAY 10 1968

STATE OF OREGON
within 30 days from the date LENGINEER, SALEM OREGON 27310
of well completion. SALEM. OREGON

(1) OWNER:	(11) LOCATION OF WELL:
Name RONALD CHRISTOFFERSON	County MARION Driller's well number
Address 4220 KALE NE, SALEM, OREGON	NE % NE % Section 6 T. 7 S R. 2 W W.M.
(2) TYPE OF WORK (check):	Bearing and distance from section or subdivision corner
	App. 700' S. NE Cor/ Sec 6
New Well ☐ Deepening ☐ Reconditioning A Abandon ☐ If abandonment, describe material and procedure in Item 12.	4220 Kale NE Salem, Ore.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(12) WELL LOG: Diameter of well below casing
Cable Jetted Domestic Industrial Municipal Dug Bored Irrigation T Test Well Other	Depth drilled O ft. Depth of completed well 117 ft.
	Formation: Describe color, texture, grain size and structure of materials;
CASING INSTALLED: Threaded Welded	and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change
" Diam. from NONE ft. to ft. Gage	in position of Static Water Level as drilling proceeds. Note drilling rates.
"Diam from ft. to ft. Gage	MATERIAL From To SWL
ft. toft. Gage	Original well drilled
PERFORATIONS: Perforated? Yes No.	in 1948 8" to 117'
Type of perforator used Original only	
Size of perforations in by in.	Listed as torch perforated
perforations from ft. to ft.	66668m 70' to 117'
perforations from ft. to ft.	Gravel to 4" from 117'
perforations from ft. to ft.	
perforations fromft. toft.	Well was treated with TSP
perforations from ft. to ft.	Swabbed and sand pumped.
(7) SCREENS: Well screen installed? Yes No	VI-22 1 2 1 02 0
Manufacturer's Name	Well increased in fixow from App. 200GPM to 320 GPM
Type Model No	Pump setting 105 i
Diam. Slot size Set from ft. to ft.	
Diam. Slot size Set from ft. to ft.	
(8) WATER LEVEL: Completed well.	
Static level 45 ft. below land surface Date4/30/68	
A sian pressure lbs. per square inch Date	
(9) WELL TESTS: Drawdown is amount water level is	
lowered below static level	
75	Work started 4/29/68 19 Completed 4/30/68 19
300 " 55 " 2 "	Date well drilling machine moved off of well $\frac{5}{1/68}$ 19
" 320 " 60 " 1 "	
Dellar test	Drilling Machine Operator's Certification: This well was constructed under my direct supervision. Mate-
A CONTRACT MAN	rials used and information reported above are true to my best knowledge and belief.
Artesian flow g.p.m. Date	say Orthernand III Made = 12/60
Temperature of water Was a chemical analysis made? Yes No	[Signed] Sward Luff Date 5/1/68, 19
(10) CONSTRUCTION:	Drilling Machine Operator's License No. 45
Well seal—Material usedOriginal only	- December 10.
Depth of seal ft.	Water Well Contractor's Certification:
Diameter of well bore to bottom of sealin.	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Were any loose strata cemented off?	NAME DUFFTELD BROS
Did any strata contain unusable water? Yes No	(Person, firm or corporation) (Type or print)
Type of water? depth of strata	Address 4123 BLUFF AVE S E, SALEM, ORE
	AD IN IN
Method of sealing strata off	[Signed] (Water Well populator)
Was well gravel packed? ☐ Yes ☐ No Size of gravel:	
Gravel placed from ft. to ft.	Contractor's License No. 15 Date May 1 1960