

RECEIVED  
NOV 14 1958

MAR. 10 6 78

STATE ENGINEER WATER WELL REPORT  
SALEM, OREGON STATE OF OREGON

6-6444  
6154

501  
7/2W-6A(1)  
State Well No. 61410  
State Permit No. 61410

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

(1) OWNER: Pierre Saucy  
Name  
Address 5650 Portland Road  
Salem, Oregon

(2) LOCATION OF WELL:  
County Marion Owner's number, if any—  
NE 1/4 NE 1/4 Section 6 T. 7 S. R. 2 W. W.M.  
Bearing and distance from section or subdivision corner well is located  
N. 89 deg. 42' W. 80.84 chains and N. 3.227 chains from the SE corner of the W. B. Stephens D.I.C. in T. 6 & 7 S. R. 2 W. Marion County, Oregon

(3) TYPE OF WORK (check):  
New Well  Deepening  Reconditioning  Abandon   
On abandonment, describe material and procedure in Item 11.

PROPOSED USE (check):  
Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(5) TYPE OF WELL:  
Rotary  Driven   
Cable  Jetted   
Dug  Bored

(6) CASING INSTALLED:  
10" Diam. from Top 125 ft. to 125 ft. Gage 31.20#  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:  
Type of perforator used MILLS Perforated?  Yes  No  
SIZE of perforations 1/4 in. by 1 1/4 in.  
70 perforations from 61 ft. to 66 ft.  
80 perforations from 74 ft. to 79 ft.  
90 310 perforations from 90 ft. to 125 ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

(8) SCREENS:  
Well screen installed  Yes  No  
Manufacturer's Name  
Type Model No.  
Slot size Set from ft. to ft.  
Slot size Set from ft. to ft.

(9) CONSTRUCTION:  
Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.  
Was a surface seal provided?  Yes  No To what depth? 20 ft.  
Material used in seal— Puddled clay & Drill cutting  
Did any strata contain unusable water?  Yes  No  
Type of water? Depth of strata  
Method of sealing strata off

(10) WATER LEVELS:  
Static level 35 ft. below land surface Date Oct. 6, 1958  
Artesian pressure lbs. per square inch Date

Log Accepted by: [Signature]  
[Signed] Date Oct 07 1958

(11) WELL TESTS:  
Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom? Driller  
Yield: gal./min. with ft. drawdown after hrs.  
" " " " "  
" " " " "  
Bailer test gal./min. with ft. drawdown after hrs.  
Artesian flow g.p.m. Date  
Temperature of water 56 Was a chemical analysis made?  Yes  No

(12) WELL LOG:  
Diameter of well 10 inches.  
Depth drilled 125 ft. Depth of completed well 125 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top Soil	0	3
Brown sandy clay	3	15
Brown silt & clay	15	58
Brown sand & gravel	58	70
Black sand & gravel	70	79
Brown sandy clay	79	88
Brown sand & gravel	88	94
Black gravel	94	102
Black sand & gravel	102	125

\*\*\*PUMP TEST\*\*\*

650 G.P.M. Max.	@ 100 ft.	Plus
550 "	@ 99 ft.	
500 "	@ 93 ft.	
450 "	@ 83 ft.	
400 "	@ 76 ft.	
350 "	@ 71 ft.	
300 "	@ 67 ft.	

Work started Sept. 19, 1958 Completed Oct. 6 19 58

(13) PUMP:  
Manufacturer's Name  
Type: H.P.

Well Driller's Statement:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Max Wymore (Person, firm, or corporation) (Type or print)  
Address Rt. 2 Salem, Oregon

Driller's well number 454  
[Signed] [Signature] (Well Driller)  
License No. 24 Date Oct. 8, 1958, 19