

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy  
of this report are to be  
filed with the

WATER WELL REPORT

MAR 6708  
6708  
75/2W-7 48

STATE OF OREGON

State Well No. 75/2W-7

STATE ENGINEER, SALEM, OREGON  
within 30 days from the date  
of well completion.

(Please type or print)

State Permit No.

RECEIVED  
SEP 12 1973

(1) OWNER:

STATE ENGINEER

Name Bernard Stewart sheet 1 of 2  
Address 4374 41st St. N.E.  
Salem, Oregon

(2) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
Dug  Bored

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(5) CASING INSTALLED:

Threaded  Welded   
10" Diam. from #1 ft. to 245 ft. Gage .250  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated?  Yes  No.

Type of perforator used Mills Knife  
Size of perforations 2 1/2 in. by 3/8 in.  
300 perforations from 135 ft. to 151 ft.  
320 perforations from 170 ft. to 190 ft.  
336 perforations from 224 ft. to 241 ft.

(7) SCREENS:

Well screen installed?  Yes  No

Manufacturer's Name  
Type Model No.  
Diam. Slot size Set from ft. to ft.  
Dia. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom? Stettler  
yield: 400 gal./min. with 102 ft. drawdown after 24 hrs.  
570 " 164 " 12 "  
" 500 " 130 " 8 "  
Bailer test gal./min. with ft. drawdown after hrs.  
Artesian flow g.p.m.  
Temperature of water 56 Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Portland Cement  
Well sealed from land surface to 35 ft.  
Diameter of well bore to bottom of seal 14 in.  
Diameter of well bore below seal 10 in.  
Number of sacks of cement used in well seal 11 sacks  
Number of sacks of bentonite used in well seal sacks  
Brand name of bentonite  
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.  
Was a drive shoe used?  Yes  No Plugs Size: location ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? depth of strata  
Method of sealing strata off  
Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Marion Driller's well number P?TP  
NW 1/4 NW 1/4 Section 7 T. 7S R. 2W W.M.  
Bearing and distance from section or subdivision corner  
4605 41st N.E.

(11) WATER LEVEL: Completed well.

Depth at which water was first found 58 ft.  
Static level 45 ft. below land surface. Date 8/26/73  
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 10  
Depth drilled 247 ft. Depth of completed well 246 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
top soil	0	5	
clay brown	5	45	
clay brown sandy	45	55	
sand brown	55	58	32
sand and gravel	58	65	"
clay gray	65	75	0
clay brown sandy	75	78	
clay brown sandy hard	78	84	
clay gray	84	91	
cemented gravel/sand	91	132	45
brown clay gravel/sand	132	148	"
gray clay gravel/sand	148	154	"
brown clay gravel/sand			
silt	154	156	"
gray clay gravel/sand	156	159	"
brown clay gravel/sand	159	161	"
gravel/fine sand	161	164	"
gravel cemented w/sand	164	169	0
gravel cemented gray clay	169	170	48

Work started 8/12/73 19 Completed 8/25 1973  
Date well drilling machine moved off of well 8/26 1973

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Paul Belles Date 9/11, 1973  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 877

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Howard H. Duffield  
(Person, firm or corporation) (Type or print)

Address 4123 Bluff Ave SE Salem, Ore.

[Signed] Howard H. Duffield  
(Water Well Contractor)

Contractor's License No. 15 Date August 31, 1973



MARI 6708

For Official Use Only:

Received Date:

County Well Log ID #

Well Identification Tag #

Mari 6708

50386

WELL IDENTIFICATION APPLICATION FORM

BUYER/CURRENT WELL OWNER:

Name: Jim West, Water Superintendent, City of Salem Public Works

Mailing Address: 1410 20th Street SE, Building No. 2

City: Salem State: OR Zip: 97302 Phone: (503) 588-6063

NOTE: Well Identification Tag will be sent to the above address unless otherwise specified.

WELL LOCATION:

Latitude Longitude

County: MARI Owner's Well Number (1st or 2nd, etc) JANREE #7
Township: 7 N or S Range: 2 E or W Section 06 CD 1/4 SE 1/4 SW

Tax Lot Number: 6900 Type of Well: water supply MUNIC monitoring

Address of Well (if different from above): 4469-41st St, NE, Salem, OR

Does this well have a formal water right associated with it? Yes: X No:

If Yes: Application #: 6-6222 Permit #: 6-6841 Certificate #: 8558

WELL INFORMATION: (do not complete remainder of application if well log is attached)

MARI-6708

Start Card Number: Approx. Construction Date:

Well Constructor:

Name of Land Owner at Time of Construction:

Well Depth (in feet): Static Water Level (in feet):

Diameter of Exposed Well Casing (in inches):

Please Return Completed Form to:

Well Identification Program
Oregon Water Resources Department
158 12th Street NE
Salem, OR 97301-4172

RECEIVED

MAY 21 2001

WATER RESOURCES DEPT.
SALEM, OREGON

50386