NOTICE TO WATER WELL DOTTE CTOR
The original and first copy it the resert WATER WELL REPORT
are to be filed with the

WATER RESOURCES DEPARTMENT, 6
SALEM, OREGON 97310

SALEM. OREGON

SALEM. OREGON

Within 30 days from the Period RESOURCES DEPT. Please type or print)

SALEM. OREGON

SALEM. OREGON

(Do not write above this line)

State Well No. 75/2W-7d	6
State Permit No.	-

(1) OWNER:	(10) LOCATION OF WELL:	
Name CHEMEKETA COMMUNITY COLLEGE	County MARION Driller's well number B-101	
Address 4000 LANCASTER DR. N.K.	NW 4 SE 4 Section 7 T.75 R. ZW W.M.	
SALKING OR 97309	Bearing and distance from section or subdivision corner	
(2) TYPE OF WORK (check):		
New Well		
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 58 ft.	
Rotary Cable Driven Domestic Industrial Municipal D	Static level 30 ft. below land surface. Date 3-15-7	
Dug ☐ Bored ☐ Irrigation ☐ Test Well ☐ Other ☐	Artesian pressure O lbs. per square inch. Date	
CASING INSTALLED: Threaded D Welded		
Timedada Weided	(12) WELL LOG: Diameter of well below casing 8"	
"Diam from t to 14.3 ft. Gage 250	Depth drilled 146 ft. Depth of completed well 146 ft.	
" Diam. fromft. toft. Gage	Formation: Describe color, texture, grain size and structure of materials;	
	and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in	
PERFORATIONS: Perforated? Yes No.	position of Static Water Level and indicate principal water-bearing strata.	
Type of perforator used	MATERIAL From To SWL	
Size of perforations in. by in.	TOP SOIL 0' 3'	
perforations from ft. to ft.	CLAY, BROWN SOFT 3' 27	
perforations fromft. toft.	CLAY, BLUE, SOFT 27 35	
perforations from ft. to ft.	CLAY, BLUK, SOFT, KANDOM SM. GR. 35 43	
(7) SCREENS: Well screen installed? I Ves No	CLAY BLUE, MED. GRAVEL TO 112" 43 58	
(7) SCREENS: Well screen installed? Yes No	SAND, BLOWN, CLAY & GRAVEL POLICER 58 64 33	
Type Model No	SAND BROWN COARSK UNIFORM 64 71 "	
Diam. Slot size Set from ft. to ft.	SAND BROWN, COARSH SOME GRAVE 71 86 " SAND BLACK MED GRAW SIZE 86 88 "	
Diam. Slot size Set from ft. to ft.	SAND, BROWN, CARSE, SOME GRULL 88 102 "	
(0) WEST I MESCURE Drawdown is an authorized to	CONGLOMERATIC 102 110 "	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	SAND BROWN, 6RAWAL '12" TO 21/2" 110 137 "	
Was a pump test made? X Yes \(\subseteq \text{No If yes, by whom?} \)	SAND BROWN, MRD. GRAW, UNIFOLA 137 139 4	
yield: 295 gal./min. with 95 ft. drawdown after 4 hrs.	SAND BROWN GRAVEL 1" TO 3" 139 143 "	
" "	CONGLOMERATE 143 146 30	
n n n		
Bailer test gal./min. with ft. drawdown after hrs.		
Artesian flow Q g.p.m.		
perature of water 53 Depth artesian flow encountered ft.	Work started 3/8 1978 Completed 5-12 1978	
(9) CONSTRUCTION:	Date well drilling machine moved off of well $1/-22$ 19 78	
Well seal—Material used PORTLAND CEMENT	Drilling Machine Operator's Certification:	
Diameter of well bore to bottom of sealin.	best knowledge and belief.	
Diameter of well bore below seal	[Signed] AMES JAO (Og KAR) Date 12 - 4, 1978	
How was cement grout placed? PRESSURE 6 ROUT	Drilling Machine Operator's License No. 1162	
FROM BOTTOM OF SEAL TO TOP.		
	Water Well Contractor's Certification:	
	This well was drilled under my jurisdiction and this report is	
Was a drive shoe used? X Yes 🗆 No Plugs Size: location	true to the best of my knowledge and belief. Name Name None	
Did any strata contain unusable water? 🛘 Yes 💢 No	(Person, firm or corporation) (Type or print)	
Type of water? depth of strata	Address CHEMEKEN COMMUNITY COLLEGE	
Method of sealing strata off	March Carbon ex	
Was well gravel packed? ☐ Yes No Size of gravel: [Signed]		
Gravel placed from ft. to ft.	Contractor's License No. 702 Date 12-4 1978	