

MARI. (6.738)

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

RECEIVED
STATE ENGINEER
APR 14 1965
STATE OF OREGON
(Please type or print)

State Well No. 7/2w-7
State Permit No. _____

(1) OWNER:

Name SACRED HEART ACADEMY
Address LANCASTER DRIVE N.E.
SALEM ORE.

(2) LOCATION OF WELL:

County MARION Driller's well number _____
1/4 Section 7 T. 7S R. 2W W.M.
Bearing and distance from section or subdivision corner _____

(3) TYPE OF WORK (check):

Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Rotary Driven
Irrigation Test Well Other Cable Jetted
Dug Bored

(5) TYPE OF WELL:

(6) CASING INSTALLED:

Threaded Welded
10" Diam. from 0 ft. to 147 ft. Gage 7
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used MILLS TYPE
Size of perforations 3/8" in. by 3" in.
50 perforations from 74'6" ft. to 76'6" ft.
650 perforations from 87' ft. to 139'6" ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal BENTONITE
Depth of seal 47' ft. Was a packer used? yes
Diameter of well bore to bottom of seal 14" in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusable water? Yes No
Type of water? MUDDY Depth of strata 77'6" TO 85'
Method of sealing strata off CASED

(10) WATER LEVELS:

Static level 14' ft. below land surface Date 4-3-65
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level. STETTLER SUPPLY
Was a pump test made? Yes No If yes, by whom?
Yield: 600 gal./min. with 29 ft. drawdown after 2 hrs.
" 700 " 35 " 1 "
" " " " "
" " " " "
Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water 54° Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 10"
Depth drilled 147 ft. Depth of completed well 147' ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
GRAVEL FILL	0	2
TOPSOIL	2	4
CLAY YELLOW COLOR	4	18
CLAY BLUE SANDY	18	36
CLAY BLUE STICKY	36	47
CONGLOMERATE	47	52'6"
GRAVEL 3" + FINE SAND	52'6"	54
CONGLOMERATE	54	62
MUDDY GRAVEL + FINE SAND	62	74
CONGLOMERATE	74	76
GRAVEL - COARSE TO FINE	76	77'6"
SAND + GRAVEL - MUDDY	77'6"	85'
CONGLOMERATE - W.B.	85	97
CLAY YELLOW COLOR	97	99
CONGLOMERATE - BLUE	99	103
CONGLOMERATE - YELLOW.	103	118
CONGLOMERATE - BLUE	118	125'
CONGLOMERATE - YELLOW.	125	138
GRAVEL - COARSE	138	140
CONGLOMERATE	140	147

Work started 3-25 1965 Completed 4-3 1965
Date well drilling machine moved off of well 4-3 1965

(13) PUMP:

Manufacturer's Name _____
Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J.A. SNEED & SONS
(Person, firm or corporation) (Type or print)

Address 3910 SILVERTON RD. SALEM ORE.

Drilling Machine Operator's License No. 187

[Signed] J.A. Sneed.
(Water Well Contractor)

Contractor's License No. 6 Date 4-5- 1965