

← Notice

MAR 1965

7/2W-8G

State Permit No.

Name E.C.Cazzell
Address 6515 Lardon Rd.
Salem, Ore.

County Marion Owner's number, if any—
SW 1/4 NE 1/4 Section 8 T. 7S R. 2W W.M.
 Bearing and distance from section or subdivision corner
750' ± N 9° E & 175' W from
SE Corner of Martin DLC

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
 If ~~Abandonment~~, describe material and procedure in Item 11.

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

Rotary	☐	Driven	☐
Cable	☒	Jettied	☐
Dug	☐	Bored	☐

(6) CASING INSTALLED: Threaded ☐ Welded ☒
 8 5/8" Diam. from 140 ft. to 100 ft. Gage 250
 " Diam. from ft. to ft. Gage
 " Diam. from ft. to ft. Gage

Type of perforator used

SIZE of perforations	in. by	in.
perforations from	ft. to	ft.
perforations from	ft. to	ft.
perforations from	ft. to	ft.
perforations from	ft. to	ft.
perforations from	ft. to	ft.

Manufacturer's Name

Type Model No.

..... Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

Was well gravel packed? ☐ Yes ☒ No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Was a surface seal provided? ☐ Yes ☐ No To what depth? _____ ft.
Material used in seal— _____

Did any strata contain unusable water? ☐ Yes ☒ No

Type of water? _____ Depth of strata _____

Method of scaling strata off

Static level 18 ft. below land surface Date 12/30/60
Artesian pressure _____ lbs. per square inch Date _____

Log Accepted by:

[Signed] E. Cagill Date _____, 19____
(Owner)

Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☐ No If yes, by whom?

Yield:	gal./min. with	ft. drawdown after	hrs.
"	"	"	"
"	"	"	"

Bailer test 50 gal./min. with 62 ft. drawdown after 7 hrs.

Artesian flow	g.p.m.	Date
---------------	--------	------

Temperature of water Was a chemical analysis made? ☐ Yes ☐ No

Diameter of well8..... inches.

Depth drilled 100 ft. Depth of completed well 100 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

[illegible]

Work started 12/26 19 60 Completed 12/29/60 19

Manufacturer's Name
Type: H.P.

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Robinson Drilling & Supply
(Person, firm, or corporation) (Type or print)

Address 140 Pine St NE Salem, Ore.

Driller's well number 7/2W-8G

[Signed] Harry G. Robinson
(Well Driller)

License No. 22 Date 12/30/60, 1960