

NOTICE TO WATER WELL CONTRACTOR
The original and first
of this report are to
be filed with the

RECEIVED
MAY 3 - 1972
STATE ENGINEER
SALEM, OREGON

6821
MAR 1972

STATE ENGINEER (Please type or print)
SALEM, OREGON (Do not write above this line)

State Well No. 7/2W-8
G-5400
State Permit No. 6-8107

(1) OWNER:

Name Tex Vickery Corp.
Address 1223 Edgewater St NW, 97304 Salem.

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
12" Diam. from 41 ft. to 174 ft. Gage 250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(6) PERFORATIONS:

Perforated? Yes No
Type of perforator used Milks
Size of perforations 1/2 in. by _____ in.
732 perforations from 85 ft. to 115 ft.
456 perforations from 123 ft. to 160 ft.
_____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: 335 gal./min. with 68 ft. drawdown after 68 hrs.
625 " 121 " 74 "
480 " 69 " 24 "
Bailer test gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow g.p.m. _____
Temperature of water _____ Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Well seal—Material used Cement Grout
Well sealed from land surface to 30 ft.
Diameter of well bore to bottom of seal 16 in.
Diameter of well bore below seal 12 in.
Number of sacks of cement used in well seal 81 sacks
Number of sacks of bentonite used in well seal _____ sacks
Brand name of bentonite _____
Number of pounds of bentonite per 100 gallons _____
of water _____ lbs./100 gals.
Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County Mason Driller's well number _____
_____ 1/4 Section 8 T. 7S R. 2W W.M.
Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.

Depth at which water was first found 27 ft.
Static level 15 ft. below land surface. Date 4-12-72
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing _____
Depth drilled 174 ft. Depth of completed well 174 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Brown Clay	0	27	
Blue Sandy Clay	27	53	
Small Gravel	53	55	
Cemented Gravel	55	60	
Med. Sand Gravel & Sand	60	67	
Black Sand	67	73	
Brown Sand - Small Gravel	73	80	
Small to med Gravel	80	91	
Brown Sand			
Cemented Gravel	91	103	
Small to med Gravel	103	113	
Cemented Gravel	113	117	
Sand & Stone Gravel	117	119	
Cemented Gravel	119	144	
Small to Large Gravel	144	147	
Cemented Gravel	147	174	

Work started 3-23 1972 Completed 4-11 1972
Date well drilling machine moved off of well 4-12 1972

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Norman P. Kerrell Date 4/12, 1972
(Drilling Machine Operator)

Drilling Machine Operator's License No. 455

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Robinson Co. Drilling
(Person, firm or corporation) (Type or print)

Address 4510 Dallas Rd NW, Salem.

[Signed] George H. Robinson
(Water Well Contractor)

Contractor's License No. 13 Date 4/12, 1972