

DATA COLLECTION SHEET

WELL I.D. # L _____

(1) LAND OWNER Owner Well Number _____
 First Name Robert E. Last Name Beaver
 Company _____
 Address 10415 72nd Ave NE R+ 6
 City Salem State OR Zip 97305

(2) TYPE OF WELL Water Well Monitoring Well Piezometer

(3) CURRENT OBSERVED USE
 Domestic Community Industrial Irrigation
 Thermal Injection Livestock Other _____

(4) BORE HOLE CONSTRUCTION Estimated Depth of Well 128 ft.

BORE HOLE			SEAL			Sacks / Pounds
Diameter	From	To	Material	From	To	

(5) CASING/LINER

Diameter	From	To	Gauge	Steel	Plastic	Welded	Threaded
Casing: <u>10"</u>	<u>0</u>	<u>128</u>		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Liner:				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Drive Shoe used Inside Outside None
 Final location of shoe(s) _____

(6) PERFORATIONS/SCREENS

Perforations Screens Type _____ Material _____

From	To	Approx Slot Size	Number	Diameter	Tele/pipe size	Casing	Liner
						<input type="checkbox"/>	<input type="checkbox"/>
						<input type="checkbox"/>	<input type="checkbox"/>

(7) WELL TESTS Date 4/23/1992

Pump Bailer Air Flowing Artesian

Yield gal/min	Drawdown	Drill stem at	Time
<u>320</u>	<u>37' 9"</u>		<u>4 hrs</u>

Temperature of water _____
 Was a water analysis done? Yes By whom _____

(8) LOCATION OF WELL (legal description)
 County Marion County Map No. _____
 Township 6 N 6 Range 2 E W WM Section 10
NW 1/4 of the NE 1/4 Tax Lot _____ Lot _____
 Lat _____ " or _____ DMS or DD
 Long _____ " or _____ DMS or DD
 Street Address of Well (or nearest address) 660 ft N & 1280 ft E
fr SW cor, DLC 58

(9) STATIC WATER LEVEL (see (11))
 _____ ft. below land surface. Date _____
 Artesian pressure _____ lb. per square inch Date _____

(10) WATER BEARING ZONES

From	To	Estimated Flow Rate	SWL

(11) LITHOLOGY Ground Elevation _____

Material	From	To
<u>From Application G-5562, depth to water is +/- 20 ft</u>		
<u>From survey notes dated 5/16/1972 by Field Engineer R.S. Muckern, Mrs. Beaver stated that the well "draws down to 20-25" and overflows in winter</u>		
<u>A pump test submitted for the well on Permit G-4915 (App G-5562) indicates a static water level of 22' 3" below land surface (m.p. = 2'), dated 4/23/1992</u>		

Estimated date originally constructed prior to 7/1/1971 (priority date)

SOURCE OF DATA / INFO USGS On-Site Observation
 Interview Other _____
Application G-5562, survey notes from 5/16/1972 found in Application file, and pump test submitted for this water right dated 4/23/1992

COMPILED BY Halley Barnett, groundwater section
 DATE 4/18/2019