

MIR. 6880

WATER WELL REPORT
STATE OF OREGON

State Well No. 7/2w-8R(1)
State Permit No. G732

OWNER:

Name RALPH ADAMS, JR.
Address 1165 COLUMBIA ST.
SALEM OREGON

(2) LOCATION OF WELL:

County MARIAN Owner's number, if any - G-732
1/4 Section 8 T. 7 S R. 2 W W.M.
Bearing and distance from section or subdivision corner
1337' N 77°23' W OF THE
SE CORNER OF SECTION 8

TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
8" Diam. from 1' ft. to 119' ft. Gage 9/16
" Diam. from " ft. to " ft. Gage
" Diam. from " ft. to " ft. Gage

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used
SIZE of perforations in. by in.
perforations from " ft. to " ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.

SCREENS:

Well screen installed Yes No
Manufacturer's Name _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

CONSTRUCTION:

Well gravel packed? Yes No Size of gravel: _____
Level placed from _____ ft. to _____ ft.
Was a surface seal provided? Yes No To what depth? 16" + ft.
Material used in seal - PUMP
Did any strata contain unusable water? Yes No
Type of water? IRON Depth of strata 94' TO 97'
Method of sealing strata off BACK FILL

(10) WATER LEVELS:

Static level 13' ft. below land surface Date 3-24-58
Artesian pressure _____ lbs. per square inch Date _____

Log Accepted by:

[Signed] Ralph Adams Date 3-24-58
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level STETTLER SUPPLY
Was a pump test made? Yes No If yes, by whom?
Yield: 210 gal./min. with 70 ft. drawdown after 2 hrs.
" 125 " 54 " 1 "
" 95 " 23 " 1 "
Bailer test gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow g.p.m. Date _____
Temperature of water 53° Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 8" 1-D inches.
Depth drilled 119 ft. Depth of completed well 119 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
<u>TCP 2014</u>	<u>3'</u>	<u>3'</u>
<u>CLAY YELLOW COLOR</u>	<u>25'</u>	<u>28'</u>
<u>CLAY BLUE COLOR SANDY</u>	<u>25'</u>	<u>53'</u>
<u>CEMENTED GRAVEL #4"</u>	<u>20'</u>	<u>73'</u>
<u>BLUE CLAY SANDY</u>	<u>7'</u>	<u>80'</u>
<u>CEMENTED GRAVEL #4"</u>	<u>14'</u>	<u>94'</u>
<u>WATER SAND + GRAVEL #3"</u>	<u>3'</u>	<u>97'</u>
<u>SAND - MEDIUM GRAIN</u>	<u>1'6"</u>	<u>98'6"</u>
<u>CLAY - YELLOW - SANDY</u>	<u>4'6"</u>	<u>103'</u>
<u>CEMENTED GRAVEL #3"</u>	<u>15'</u>	<u>118'</u>
<u>WATER GRAVEL #3"</u>	<u>1'</u>	<u>119'</u>

WATER AT 94 TO 97' CONTAINS
IRON MINERAL - NOT SATISFACTORY
FOR DOMESTIC USE

CASING EQUIPPED WITH HEAVY
STEEL DRIVING SHOES

Work started 3-18 1958 Completed 3-24 1958

(13) PUMP:

Manufacturer's Name Berkeley Turbine
Type: _____ H.P. 3 H.P.

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J. A. SHEED + SONS
(Person, firm, or corporation) (Type or print)

Address 2505 BROOKS ST SALEM ORE

Driller's well number _____

[Signed] J. A. Sheed
(Well Driller)

License No. 60 Date 3-24, 1958