

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER WELL REPORT

WATER RESOURCES DEPARTMENT
SALEM, OREGON 97310
within 30 days from the date
of well completion.

RECEIVED

STATE OF OREGON
(Please type or print)

APR 23 1979

State Well No. 73/2W-9ba
State Permit No. 6-8462

(1) OWNER: WATER RESOURCES DEPT.
SALEM, OREGON

Name Wayne Goode
Address 972 Goode Lane
Silverton, Oregon 97381

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
 Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
8" Diam. from +1 ft. to 154 ft. Gage 250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(6) PERFORATIONS:

Perforated? Yes No.

Type of perforator used Mill's Knife
Size of perforations 3/8 in. by 2 in.
600 perforations from 150 ft. to 100 ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____ Model No. _____
Type _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? Driller
d: 100 gal./min. with 36 ft. drawdown after 1 hrs.
" 200 " " 56 " " 2 "
" 340 " " 93 " " 2 "
Bailer test gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow g.p.m. _____
Temperature of water _____ Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Well seal—Material used portland cement
Well sealed from land surface to 25 ft.
Diameter of well bore to bottom of seal 12 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 15 sacks
How was cement grout placed? air grout pump

Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County Marion Driller's well number _____
NE 1/4 NW 1/4 Section 9 T. 7S R. 2W W.M. _____
Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.

Depth at which water was first found 69 ft.
Static level 17 ft. below land surface. Date 2-26-79
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 0"
Depth drilled 154 ft. Depth of completed well 154 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Brown topsoil	0'	4'	
Brown clay	4'	51'	
Blue clay	51'	56'	
Black fine-medium sand	56'	69'	
Black sand & gravel	69'	83'	
Brown clay & gravel	83'	84'	
Brown small-medium gravel & sand	84'	96'	
Brown sand & gravel (slightly cemented)	96'	123'	17'
Black small-large gravel & fine-medium sand	123'	138'	
Black sand & gravel with some blue clay	138'	154'	17'

Work started Feb. 21 19 79 Completed March 14 19 79
Date well drilling machine moved off of well March 15 19 79

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Michael Waldrop Date 3-15, 19 79
(Drilling Machine Operator)

Drilling Machine Operator's License No. 873

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name MILLER & WEST DRILLING
(Person, firm or corporation) (Type or print)

Address 5875 GATTIN RD. SE

[Signed] Michael Waldrop
(Water Well Contractor)

Contractor's License No. 633 Date 3-15, 19 79