

**NOTICE TO WATER WELL CONTRACTOR**

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

**RECEIVED**  
MAY 5 1964  
STATE ENGINEER

**WATER WELL REPORT**

STATE OF OREGON  
(Please type or print)

G-3524

State Well No. 7/2W-9K

State Permit No. \_\_\_\_\_

**(1) OWNER:**

Name (GHAS) BEN NANNEMAN  
Address 5662 SILVERTON RD. N.E. SALEM ORE

**(2) LOCATION OF WELL:**

County MARION Driller's well number \_\_\_\_\_  
1/4 Section 9 T. 7 R. 2W W.M.  
Bearing and distance from section or subdivision corner \_\_\_\_\_

**TYPE OF WORK (check):**

Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal  Irrigation  Test Well  Other

**(5) TYPE OF WELL:**

Rotary  Cable  Dug  Driven  Jetted  Bored

**(6) CASING INSTALLED:**

Threaded  Welded   
10" Diam. from 0 ft. to 144 ft. Gage 32#  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

**(7) PERFORATIONS:**

Perforated?  Yes  No  
Type of perforator used MILLS  
Size of perforations 9/16" in. by 3" in.  
820 perforations from 83' ft. to 141 ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(8) SCREENS:**

Well screen installed  Yes  No  
Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(9) CONSTRUCTION:**

Well seal—Material used in seal BENTONITE  
Depth of seal 50' ft. Was a packer used? yes  
Diameter of well bore to bottom of seal 14" in.  
Were any loose strata cemented off?  Yes  No Depth \_\_\_\_\_  
Was a drive shoe used?  Yes  No  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? SANDY Depth of strata 54' TO 67'  
Method of sealing strata off CASED

**(10) WATER LEVELS:**

Static level 21 ft. below land surface Date 4-30-64  
Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

**(11) WELL TESTS:**

Drawdown is amount water level is lowered below static level STETTLER  
Was a pump test made?  Yes  No If yes, by whom? SUPPLY  
Yield: 350 gal./min. with 30 ft. drawdown after 1 hrs.  
" 450 " 40 " 1 "  
" 650 " 56 " 1 "  
Bailer test NO gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Artesian flow \_\_\_\_\_ g.p.m. Date \_\_\_\_\_  
Temperature of water 55° Was a chemical analysis made?  Yes  No

**(12) WELL LOG:**

Diameter of well below casing 10"  
Depth drilled 144' ft. Depth of completed well 144' ft.  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOPSOIL	0	3
CLAY-YELLOW-SILTY	3	44
CLAY BLUE	44	54
SAND BLACK FINE	54	67
SAND COARSE	67	68
CONGLOMERATE-YELLOW	68	80
CONGLOMERATE-BLUE	80	84
GRAVEL COARSE	84	85'6"
CLAY BLUE COLOR	85'6"	88
CONGLOMERATE-YELLOW	88	105
GRAVEL COARSE W.B.	105	107
CONGLOMERATE-YELLOW	107	130
GRAVEL COARSE	130	132
CONGLOMERATE W.B.	132	144

Work started 4-26 19 64 Completed 4-30 19 64  
Date well drilling machine moved off of well 4-30 19 64

**(13) PUMP:**

Manufacturer's Name \_\_\_\_\_  
Type: \_\_\_\_\_ H.P. \_\_\_\_\_

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J.A. SNEED & SONS (Person, firm or corporation) (Type or print)  
Address 3910 SILVERTON RD. SALEM, O.  
Drilling Machine Operator's License No. 187  
[Signed] A.J. Sneed (Water Well Contractor)  
Contractor's License No. 6 Date 5-3, 1964

State Engineer

Dear Sir,

We do not have the pump size,  
however the owner will know  
his definite size after he  
discusses with pump man &  
will inform you when he  
applies for a permit

RECEIVED

MAY 5 1964

STATE ENGINEER  
D. C. CRAB...

yours truly  
D. F. Sneed