The original and first copy of this report are to be MAY 18 1970 STATE OF OREGON tiled with the

STATE ENGINEER, SALEM, ORECON STATE ENGINEERS type or print) within 30 days from the dall ATE ENGINEERS type or print) of well completion. SALEM, OREGON

State Permit No.

(1) OWNER:	(11) LOCATION OF WELL:			
Name North MARION JR. High School	County MARION Driller's well nu	mber	36	
Address PACIFIC Hy. Hubbard, ORE	14 14 Section 22 T. 43	R/	W	W.M.
	Bearing and distance from section or subdivision	1 corner		
(2) TYPE OF WORK (check):				
New Well Deepening Reconditioning Abandon	•			
If abandonment, describe material and procedure in Item 12.				
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(12) WELL LOG: Diameter of well to	elow cas	ing	10
Rotary Driven Domestic Industrial Municipal	Depth drilled 130 ft. Depth of comple	eted well	12	8 n.
Dug	Formation: Describe color, texture, grain size			aterials:
CASING INSTALLED: Threaded Welded	and show thickness and nature of each stratu- with at least one entry for each change of form	m and ac ation. Re	quifer per eport each	netrated, n change
10 " Diam from 1 1 to 1262 ft. Gage 250	in position of Static Water Level as drilling pro			
"Diam. from	MATERIAL	From	To	SWL
" Diam. from ft. to ft. Gage	BROWN TOP SOIL	0	2	
PERFORATIONS: Perforated? W Yes No.	BROWN SANDY CLAY	2	24	
Type of perforator used MILLS KNIFE	DRY BROWN SAND	24	26	
21- 31/1	BROWN CLAY	26	39	_
	BLUE CLAY	39	73	
	FINE BLACK SAND	73	8/	
perforations from ft. to ft.	HARD BUE CLAY	8/	90	
perforations from	COURSE BL. SAND, FINE GRAVE	90	92	
perforations from ft. to ft.	BLUE CLAY	92	105	
perforations from ft. to ft.	BLACK SAND, FINE	105	107	
(7) SCREENS: Well screen installed? ☐ Yes ☑ No	FINE BLACK SAND + GRAVEL	107	116	
	BLUE CLAY	116	117	
Manufacturer's Name	POURSE BLACK SAND & GRAVEL	117	130	
Type				
Diam. Slot size Set from ft. to ft.				
Diam Slot size Set from ft. to ft.				
(8) WATER LEVEL: Completed well.				
"tatic level 40 ft. below land surface Date 4///70				
ssian pressure lbs. per square inch Date				
(9) WELL TESTS: Drawdown is amount water level is lowered below static level				
Was a pump test made? Yes □ No If yes, by whom? RILLER				
eld: 550 gal./min. with 60 ft. drawdown after 8 hrs.	Work started 3//0 1970 Complete	ed 4		1970
	Date well drilling machine moved off of well		4/ /	1970
	Drilling Machine Operator's Certification:			
The state of the s	This well was constructed under my d			
Bailer test gal./min. with ft. drawdown after hrs.	rials used and information reported above knowledge and helief	re are t	rue to r	ny best
Artesian flow g.p.m. Date		Jus	1111	. 7.
Temperature of water 54° Was a chemical analysis made? [] Yes [] No	[Signed] (Drilling Machine Operator)	Date	7	., 19. <i>70</i>
(10) CONSTRUCTION:	Drilling Machine Operator's License No	50	0	
Well seal-Material used CEMENT +BENEINITE CLAY				
Depth of seal ft.	Water Well Contractor's Certification:			
Diameter of well bore to bottom of seal	This well was drilled under my jurisd true to the best of my knowledge and beli		nd this r	eport is
Were any loose strata cemented off? Yes Mo Depth	lull A AL	iches	נהשבע	TP
Was a drive shoe used? ⊠ Yes □ No	(Person, firm or corporation)	(Typ	e or print)	W.31
Did any strata contain unusable water? Yes No	Address 6.0. 80 x 343 He	سراري	ed n	
Type of water? depth of strata	Address			
Method of sealing strata off	(Signad) ////week / Office	Mario	W/N	
	[Signed] (Water Well Contra	rtor)	····	
	Contractor's License No	41	1	1070
Gravel placed from ft. to ft.	Contractor's License No Date			10(