

RECEIVED

MARION

6945

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

OCT 5 1965 WATER WELL REPORT

State Well No. 7/2w-3 10B
State Permit No.

STATE ENGINEER, SALEM OREGON STATE ENGINEER STATE OF OREGON
within 30 days from the date of well completion. (Please type or print)
SALEM OREGON

(1) OWNER:

Name LEONARD ROTH
Address RT. 2 BOX 520 SALEM ORO.

(2) LOCATION OF WELL:

County MARION Driller's well number
1/4 1/4 Section 3 T. 7S R. 2W. W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
10" Diam. from 0 ft. to 180 ft. Gage # 7
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used MILLS
Size of perforations 3/8 in. by 2 1/2 in.
980 perforations from 105 ft. to 178 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Type Model No.
in. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal BENTONITE
Depth of seal 47' ft. Was a packer used? yes
Diameter of well bore to bottom of seal 14" in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water SANDY Depth of strata 58' TO 96'
Method of sealing strata off CASED.

(10) WATER LEVELS:

Static level 58' ft. below land surface Date 9-29-65
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level STELLER SUPPLY
Was a pump test made? Yes No If yes, by whom?
Yield: 300 gal./min. with 55 ft. drawdown after 1 hrs.
" 400 " 82 " 1 "
" " " " "
Ballor test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 54° Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 10"
Depth drilled 180' ft. Depth of completed well 180' ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOPSOIL	0	2
CLAY YELLOW COLOR	2	17
CLAY BLUE SILTY	17	30
CLAY BLUE STICKY	30	48
CLAY BROWN SANDY	48	50
CLAY BROWN STICKY	50	58
CLAY BROWN SANDY	58	96
CONGLOMERATE	96	104
GRAVEL 1"	104	105
CONGLOMERATE	105	114
GRAVEL	114	115
CONGLOMERATE	115	161
GRAVEL 1"	161	162
CONGLOMERATE	162	180

Work started 9-22-1965 Completed 9-29-1965
Date well drilling machine moved off of well 9-29-1965

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J. A. SUEED & SONS
(Person, firm or corporation) (Type or print)

Address 3916 SILVERTON RD SALEM ORO.

Drilling Machine Operator's License No. 187

[Signed] P. J. SUEED
(Water Well Contractor)

Contractor's License No. 6 Date 9-30-1965

Owner will not install a pump
until next spring.

RECEIVED
OCT 5 1935
STATE ENGINEER
DIVISION